


PROBLEM SUMMARY


Area
TM 6
 Machine Id
REEL DRUM GRBX
 Component
Gearbox
 Fluid
ROYAL PURPLE SYNERGY 90/220 (--- GAL)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

▲ Ferrous Alloys



▲ Viscosity @ 40°C



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	SEVERE
Iron	ppm	ASTM D5185m	>200	▲ 257	▲ 240	▲ 373
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT	LIGHT
Visc @ 40°C	cSt	ASTM D445	216.1	▲ 133	▲ 132	220

Customer Id: KIMMOBTM6
 Sample No.: RP0034423
 Lab Number: 05932856
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

24 May 2023 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The iron level is abnormal. All other component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report



21 Feb 2023 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The iron level is abnormal. All other component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



06 Nov 2022 Diag: Angela Borella

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The iron level is abnormal. All other component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
TM 6
Machine Id
REEL DRUM GRBX

Component
Gearbox
Fluid
ROYAL PURPLE SYNERGY 90/220 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

Gear wear is indicated.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP0034423	RP0023575	RP0030375
Sample Date	Client Info		09 Aug 2023	24 May 2023	21 Feb 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		7	18	23
Iron	ppm	ASTM D5185m >200	▲ 257	▲ 240	▲ 373
Chromium	ppm	ASTM D5185m >15	1	2	2
Nickel	ppm	ASTM D5185m >15	<1	<1	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	2	3	3
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	4	3	<1
Tin	ppm	ASTM D5185m >25	0	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	6	19
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1
Manganese	ppm	ASTM D5185m	4	4	5
Magnesium	ppm	ASTM D5185m	5	8	8
Calcium	ppm	ASTM D5185m	4	6	5
Phosphorus	ppm	ASTM D5185m 370	403	414	432
Zinc	ppm	ASTM D5185m	153	159	60

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	5	4	9
Sodium	ppm	ASTM D5185m	<1	2	<1
Potassium	ppm	ASTM D5185m >20	2	<1	1
Water	%	ASTM D6304 >0.2	0.009	0.018	0.026
ppm Water	ppm	ASTM D6304 >2000	92.7	181.6	260.5






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	72622	128937
Particles >6µm	ASTM D7647	>5000	---	7770	6635
Particles >14µm	ASTM D7647	>640	---	311	268
Particles >21µm	ASTM D7647	>160	---	79	72
Particles >38µm	ASTM D7647	>40	---	2	0
Particles >71µm	ASTM D7647	>10	---	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	23/20/15	24/20/15

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.33	0.67	0.70	1.08


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	LIGHT	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	216.1 ▲ 133	▲ 132	220

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0034423 **Received** : 23 Aug 2023
Lab Number : 05932856 **Diagnosed** : 24 Aug 2023
Unique Number : 10618127 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: PQ, PrtCount)

Kimberly-Clark - Mobile - TM 6
 200 BAYBRIDGE RD
 MOBILE, AL
 US 36610
 Contact: MORGAN RUSSELL
 Morgan.Russell@kcc.com
 T:
 F: (251)452-6335

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)