

# PROBLEM SUMMARY


Sample Rating Trend

WEAR




Area  
**TM 6**  
Machine Id  
**YANKEE GRBX**

Component  
**Gearbox**  
Fluid  
**GEAR OIL LS 80W90 (--- GAL)**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check for the source of water entry. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Please note that the oil was too thick to perform some of the normal laboratory tests.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	ABNORMAL
PQ		ASTM D8184		21003	18	15
Boron	ppm	ASTM D5185m	150	0	0	0
Calcium	ppm	ASTM D5185m	70	0	40	2
Phosphorus	ppm	ASTM D5185m	2000	13	468	231
Zinc	ppm	ASTM D5185m	50	4	689	348
Water	%	ASTM D6304	>0.2	90.6	0.007	0.009
ppm Water	ppm	ASTM D6304	>2000	906000	73.7	95.9
Acid Number (AN)	mg KOH/g	ASTM D8045		2.78	0.51	0.43
Emulsified Water	scalar	*Visual	>0.2	0.2%	NEG	NEG

Customer Id: KIMMOBTM6  
Sample No.: RP0034418  
Lab Number: 05932861  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	Please note that the oil was too thick to perform some of the normal laboratory tests.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

### 24 May 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Feb 2023 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 06 Nov 2022 Diag: Angela Borella

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Area  
**TM 6**  
Machine Id  
**YANKEE GRBX**

Component  
**Gearbox**  
Fluid  
**GEAR OIL LS 80W90 (--- GAL)**

**DIAGNOSIS**

**Recommendation**  
We advise that you check for the source of water entry. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Please note that the oil was too thick to perform some of the normal laboratory tests.

**Wear**  
The very high ferrous density (PQ) index indicates that severe wear is occurring.

**Contamination**  
There is a high concentration of water present in the oil.

**Fluid Condition**  
The oil is no longer serviceable.

**SAMPLE INFORMATION**

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>RP0034418</b>	RP0023571	RP0023420
Sample Date	Client Info		<b>09 Aug 2023</b>	24 May 2023	21 Feb 2023
Machine Age	wks	Client Info	<b>0</b>	0	0
Oil Age	wks	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	NORMAL	ABNORMAL

**WEAR METALS**

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>21003</b>	18	15
Iron	ppm	ASTM D5185m >200	<b>11</b>	3	11
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	0
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	2	1
Tin	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1

**ADDITIVES**

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 150	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	<1	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m 10	<b>&lt;1</b>	2	8
Calcium	ppm	ASTM D5185m 70	<b>0</b>	40	2
Phosphorus	ppm	ASTM D5185m 2000	<b>13</b>	468	231
Zinc	ppm	ASTM D5185m 50	<b>4</b>	689	348

**CONTAMINANTS**

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	2
Sodium	ppm	ASTM D5185m	<b>0</b>	1	3
Potassium	ppm	ASTM D5185m >20	<b>2</b>	0	0
Water	%	ASTM D6304 >0.2	<b>90.6</b>	0.007	0.009
ppm Water	ppm	ASTM D6304 >2000	<b>906000</b>	73.7	95.9






**FLUID CLEANLINESS**

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>---</b>	5518	19663
Particles >6µm	ASTM D7647	>5000	<b>---</b>	1012	4960
Particles >14µm	ASTM D7647	>640	<b>---</b>	150	<b>848</b>
Particles >21µm	ASTM D7647	>160	<b>---</b>	37	<b>194</b>
Particles >38µm	ASTM D7647	>40	<b>---</b>	2	1
Particles >71µm	ASTM D7647	>10	<b>---</b>	0	1
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>---</b>	20/17/14	<b>21/19/17</b>

**FLUID DEGRADATION**

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>2.78</b>	0.51	0.43

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 140	0.8	211	212

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0034418 **Received** : 23 Aug 2023  
**Lab Number** : 05932861 **Diagnosed** : 28 Aug 2023  
**Unique Number** : 10618132 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: PQ, PrtCount )

**Kimberly-Clark - Mobile - TM 6**  
 200 BAYBRIDGE RD  
 MOBILE, AL  
 US 36610  
 Contact: MORGAN RUSSELL  
 Morgan.Russell@kcc.com  
 T:  
 F: (251)452-6335

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)