


# PROBLEM SUMMARY

Sample Rating Trend

**DIRT**




Area  
**Thermoforming**  
Machine Id  
**Line 8 C Extruder (S/N 4276)**  
Component  
**Bevel Helical Gearbox**  
Fluid  
**SUMMIT UNIPAR FG-320 (60 GAL)**




## COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Silicon (ppm)



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. ( Customer Sample Comment: Bengamen Castillo )

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Silicon	ppm	ASTM D5185m >50	▲ <b>133</b>	▲ 84	▲ 55
Particles >4µm		ASTM D7647 >1300	▲ <b>13165</b>	▲ 18708	---
Particles >6µm		ASTM D7647 >320	▲ <b>1738</b>	▲ 1080	---
Oil Cleanliness		ISO 4406 (c) >17/15/13	▲ <b>21/18/12</b>	▲ 21/17/12	---

Customer Id: DARDALTX  
Sample No.: TO50001739  
Lab Number: 05933495  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

05 Apr 2023 Diag: Doug Bogart

DIRT



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



27 Feb 2023 Diag: Sean Felton

DIRT



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. Elemental level of silicon (Si) above normal. The condition of the oil is acceptable for the time in service.

view report



09 Feb 2023 Diag: Sean Felton

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



Area  
**Thermoforming**  
 Machine Id  
**Line 8 C Extruder (S/N 4276)**  
 Component  
**Bevel Helical Gearbox**  
 Fluid  
**SUMMIT UNIPAR FG-320 (60 GAL)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. ( Customer Sample Comment: Bengamen Castillo )

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO50001739</b>	TO50001591	TO50001399
Sample Date	Client Info	<b>18 Aug 2023</b>	05 Apr 2023	27 Feb 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	<b>13</b>	11	13	
Iron	ppm	ASTM D5185m >150	<b>5</b>	2	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>1</b>	2	<1
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>2</b>	2	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>1</b>	0	6
Calcium	ppm	ASTM D5185m	<b>4</b>	0	<1
Phosphorus	ppm	ASTM D5185m	<b>902</b>	541	497
Zinc	ppm	ASTM D5185m	<b>16</b>	5	4
Sulfur	ppm	ASTM D5185m	<b>1383</b>	917	275

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>▲ 133</b>	▲ 84	▲ 55
Sodium	ppm	ASTM D5185m	<b>0</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	0
Water	%	ASTM D6304 >0.1	<b>0.006</b>	0.005	---
ppm Water	ppm	ASTM D6304 >1000	<b>67.7</b>	57.3	---






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	<b>▲ 13165</b>	▲ 18708	---
Particles >6µm	ASTM D7647 >320	<b>▲ 1738</b>	▲ 1080	---
Particles >14µm	ASTM D7647 >80	<b>39</b>	27	---
Particles >21µm	ASTM D7647 >20	<b>12</b>	8	---
Particles >38µm	ASTM D7647 >4	<b>1</b>	0	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >17/15/13	<b>▲ 21/18/12</b>	▲ 21/17/12	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.73</b>	0.69	---


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	267	277	292
Visc @ 100°C	cSt	ASTM D445	24.6	25.2	26.5
Viscosity Index (VI)	Scale	ASTM D2270	117	116	119

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO50001739 **Received** : 24 Aug 2023  
**Lab Number** : 05933495 **Diagnosed** : 28 Aug 2023  
**Unique Number** : 10618766 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PQ, PrtCount, VI )

**DART CONTAINER CORPORATION**  
 4444 W LEADBETTER DR  
 DALLAS, TX  
 US 75236  
 Contact: YON PALOMINO  
 yon.palomino@dart.biz  
 T: (214)775-5673  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)