

PROBLEM SUMMARY

Sample Rating Trend

DEGRADATION

Machine Id

KAESER BSD 50 3171294 (S/N 1672)


Component


Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)









RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. Please note that the oil was too thick to perform some of the normal laboratory tests. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status		-001-0	SEVERE	ATTENTION					
Boron	ppm	ASTM D5185m		<u> </u>	0				
Calcium	ppm	ASTM D5185m	2	4 24	0				
Phosphorus	ppm	ASTM D5185m		107	368				
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	110.4	0.393				
Debris	scalar	*Visual	NONE	▲ MODER	NONE				
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG				
Free Water	scalar	*Visual		10.0	NEG				

Customer Id: PERGAI Sample No.: KC05933584 Lab Number: 05933584 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	We recommend that you drain the oil from the component if this has not already been done.		
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.		

HISTORICAL DIAGNOSIS

24 Sep 2015 Diag: Doug Bogart

ADDITIVES



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend **DEGRADATION**

KAESER BSD 50 3171294 (S/N 1672)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. Please note that the oil was too thick to perform some of the normal laboratory tests. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil. Excessive free water present.

Fluid Condition

The AN level is well above the recommended limit.

			Sep2015	Aug 2023		
CAMPLE INCOR	AATION	or ether d			la ta ka musik	la la tarrico
SAMPLE INFORM	MATION	method	limit/base		history1	history2
Sample Number		Client Info		KC05933584	KC03844406	
Sample Date		Client Info		16 Aug 2023	24 Sep 2015	
Machine Age	hrs	Client Info		8057	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				SEVERE	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	16	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	2	<1	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<u> 18</u>	0	
Barium	ppm	ASTM D5185m	90	7	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	90	7	<1	
Calcium	ppm	ASTM D5185m	2	<u>^</u> 24	0	
Phosphorus	ppm	ASTM D5185m		107	368	
Zinc	ppm	ASTM D5185m		24	<1	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	<1	
Sodium	ppm	ASTM D5185m		8	1	
Potassium	ppm	ASTM D5185m	>20	3	<1	
Water	%	ASTM D6304	>0.05		0.015	
ppm Water	ppm	ASTM D6304	>500		150	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			410	
Particles >6µm		ASTM D7647	>1300		223	
Particles >14µm		ASTM D7647	>80		38	
Particles >21µm		ASTM D7647	>20		12	
Particles >38µm		ASTM D7647	>4		1	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		15/12	
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
A 1 1 1 1 (AND)	1/011/	40714 00045	0.4	140.4	0.202	

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.393

110.4



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : IND 2

: KC05933584 : 05933584 : 10618855

Received Diagnosed

: 24 Aug 2023 : 28 Aug 2023 : Jonathan Hester Diagnostician

PERDUE FARMS 1155 CANDLER RD GAINESVILLE, GA

US 30507

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: