



KAESER COMPRESSORS Built for a lifetime."

KAESER SM 7.5 4492568 (S/N 1077)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





scalar *Visual

Free Water

RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC 1	FEST RE	SULTS				
Sample Status				SEVERE	NORMAL	ABNORMAL
Water	%	ASTM D6304	>0.05	A 0.191	0.003	0 .126
ppm Water	ppm	ASTM D6304	>500	<u> </u>	26.4	1 260
Particles >6µm		ASTM D7647	>1300	<u> </u>	744	789
Particles >14µm		ASTM D7647	>80	A 376	49	1 34
Particles >21µm		ASTM D7647	>20	<u> </u>	13	4 5
Particles >38µm		ASTM D7647	>4	<u> </u>	0	<u> </u>
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	17/13	▲ 17/14
Emulsified Water	scalar	*Visual	>0.05	6.2%	NEG	(0.2%

10.0

Customer Id: DEDWAR Sample No.: KC111295 Lab Number: 05933588 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u> **2**.0

NEG

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

HISTORICAL DIAGNOSIS



08 Feb 2022 Diag: Angela Borella

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

19 Dec 2018 Diag: Angela Borella



The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

06 Jun 2018 Diag: Doug Bogart



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Rating Trend

WATER

 $\mathbf{\Sigma}$

Machine Id KAESER SM 7.5 4492568 (S/N 1077)

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. Excessive free water present.


Fluid Condition


The AN level is acceptable for this fluid.


		-				
SAMPLE INFORM	ATION	method	Jun2018 limit/base	Current	Jun2023 history1	history2
Sample Number		Client Info	initia babb	KC111295	KC95639	KC79225
Sample Date		Client Info		23 Jun 2023	08 Feb 2022	19 Dec 2018
Machine Age	hrs	Client Info		21049	18162	13091
Oil Age	hrs	Client Info		21049	3059	0
Oil Changed	1113	Client Info		Changed	Changed	Not Changd
Sample Status				SEVERE	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	7	10	5
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	2	<1
Barium	ppm	ASTM D5185m	90	2	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	2	0	15
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	0	3	3
Zinc	ppm	ASTM D5185m	0	16	2	24
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		0	<1	2
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.05	<u> </u>	0.003	0 .126
ppm Water	ppm	ASTM D6304	>500	1910	26.4	1260
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4054	5832	1448
Particles >6µm		ASTM D7647		<u> </u>	744	789
Particles >14µm		ASTM D7647	>80	A 376	49	1 34
Particles >21µm		ASTM D7647		<u>▲</u> 127	13	<u>▲</u> 45
Particles >38µm		ASTM D7647	>4	<u> </u>	0	▲ 7
Particles >71µm		ASTM D7647		2	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	 19/18/16	17/13	▲ 17/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.34	0.43	0.357




OIL ANALYSIS REPORT










Ŭ

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	🔺 HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	A 0.2%	NEG	▲ 0.2%
Free Water	scalar	*Visual		e 10.0	NEG	2 .0
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.1	43.0	43.82
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						

Bottom



Report Id: DEDWAR [WUSCAR] 05933588 (Generated: 08/28/2023 09:26:11) Rev: 1

Contact/Location: SERVICE MANAGER ? - DEDWAR