


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER 6410031

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KC102771	KC96438	KC67779
Sample Date	Client Info			06 Jun 2023	16 Dec 2021	14 Aug 2019
Machine Age	hrs	Client Info		18317	12088	2539
Oil Age	hrs	Client Info		0	1983	2539
Oil Changed	Client Info			Changed	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	4	9	3
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m		---	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	23	2
Barium	ppm	ASTM D5185m	90	18	35	11
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	40	74	77
Calcium	ppm	ASTM D5185m	2	2	1	0
Phosphorus	ppm	ASTM D5185m		4	1	0
Zinc	ppm	ASTM D5185m		36	34	6

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	2
Sodium	ppm	ASTM D5185m		10	16	27
Potassium	ppm	ASTM D5185m	>20	3	1	5
Water	%	ASTM D6304	>0.05	0.022	0.011	0.018
ppm Water	ppm	ASTM D6304	>500	226.9	114.5	186.1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1483	3627	92065
Particles >6µm		ASTM D7647	>1300	532	1000	▲ 19066
Particles >14µm		ASTM D7647	>80	35	68	▲ 249
Particles >21µm		ASTM D7647	>20	8	8	▲ 46
Particles >38µm		ASTM D7647	>4	1	0	▲ 10
Particles >71µm		ASTM D7647	>3	0	0	2
Oil Cleanliness		ISO 4406 (c)	>--/17/13	18/16/12	17/13	▲ 21/15

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.40	0.344


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.5	44.3	43.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC102771 **Received** : 24 Aug 2023
Lab Number : 05933590 **Diagnosed** : 25 Aug 2023
Unique Number : 10618861 **Diagnostician** : Don Baldrige
Test Package : IND 2

MATICK AUTO GROUP
 13955 TELEGRAPH RD
 REDFORD, MI
 US 48239
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: