




PROBLEM SUMMARY

Sample Rating Trend



WATER




Machine Id
SMIMID MASSAGER 7 (S/N CK3357U00145)

Component
Gearbox

Fluid
PETRO CANADA PURITY FG EP GEAR OIL 220 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water



RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.2	▲ 0.397	0.088	0.151
ppm Water	ppm	ASTM D6304	>2000	▲ 3970	880	1510
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ HAZY	▲ HAZY
Free Water	scalar	*Visual		▲ 1.0	▲ 1.0	NEG

Customer Id: SMIMID
Sample No.: USP0000515
Lab Number: 05933722
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

04 Jun 2023 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Appearance is hazy. Moderate concentration of visible dirt/debris present in the oil. Free water present. The AN level is acceptable for this fluid.

[view report](#)



08 Mar 2023 Diag: Doug Bogart

CONTAMINANT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



29 Nov 2022 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Free water present. The oil viscosity is lower than normal. Confirmed. The AN level is acceptable for this fluid.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
SMIMID MASSAGER 7 (S/N CK3357U00145)

Component

Gearbox

Fluid

PETRO CANADA PURITY FG EP GEAR OIL 220 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil. Free water present.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP0000515	USP05864343	USP246393
Sample Date	Client Info		23 Aug 2023	04 Jun 2023	08 Mar 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	92	68	45
Chromium	ppm	ASTM D5185m	>15	<1	<1	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	<1	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		5	2	2
Phosphorus	ppm	ASTM D5185m		79	61	63
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		907	876	711

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	6	3	5
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.2	▲ 0.397	0.088	0.151
ppm Water	ppm	ASTM D6304	>2000	▲ 3970	880	1510

FLUID CLEANLINESS




	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	---	---
Particles >6µm	ASTM D7647	>5000	---	---	---
Particles >14µm	ASTM D7647	>640	---	---	---
Particles >21µm	ASTM D7647	>160	---	---	---
Particles >38µm	ASTM D7647	>40	---	---	---
Particles >71µm	ASTM D7647	>10	---	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.51	0.24	0.19	0.14




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	MODER	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ HAZY	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	0.2%	0.2%
Free Water	scalar	*Visual		▲ 1.0	▲ 1.0	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	205.8	211	212	212

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0000515 **Received** : 24 Aug 2023
Lab Number : **05933722** **Diagnosed** : 25 Aug 2023
Unique Number : 10618993 **Diagnostician** : Doug Bogart
Test Package : IND 2

SMITHFIELD FOODS-MIDDLESBORO
 MIDDLESBORO, KY
 US
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: