




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
MET EXPRESS
 Machine Id
MET EXPRESS 23004
 Component
Front Differential
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data updates of elemental data.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0843187	WC0815605	WC0728398
Sample Date	Client Info		09 Aug 2023	20 Apr 2023	28 Jul 2022
Machine Age	mls	Client Info	98161	70758	8
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	291	201	27
Chromium	ppm	ASTM D5185m >10	2	2	<1
Nickel	ppm	ASTM D5185m >10	<1	1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	<1
Aluminum	ppm	ASTM D5185m >25	3	2	0
Lead	ppm	ASTM D5185m >25	0	<1	<1
Copper	ppm	ASTM D5185m >100	2	2	<1
Tin	ppm	ASTM D5185m >10	0	0	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	499	411	571
Barium	ppm	ASTM D5185m	31	0	0
Molybdenum	ppm	ASTM D5185m	1	2	1
Manganese	ppm	ASTM D5185m	13	9	2
Magnesium	ppm	ASTM D5185m	14	6	3
Calcium	ppm	ASTM D5185m	16	20	13
Phosphorus	ppm	ASTM D5185m	2001	1934	1942
Zinc	ppm	ASTM D5185m	42	17	6
Sulfur	ppm	ASTM D5185m	25056	25252	23488

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	47	34	7
Sodium	ppm	ASTM D5185m	8	4	4
Potassium	ppm	ASTM D5185m >20	3	3	<1
Water	%	ASTM D6304 >.2	0.039	0.035	0.011
ppm Water	ppm	ASTM D6304 >2000	398.2	352.6	110.1

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 116641	▲ 125839	▲ 108382
Particles >6µm	ASTM D7647	>5000	▲ 6917	▲ 13867	▲ 10279
Particles >14µm	ASTM D7647	>640	25	27	315
Particles >21µm	ASTM D7647	>160	6	4	75
Particles >38µm	ASTM D7647	>40	0	0	6
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/20/12	▲ 24/21/12	▲ 24/21/15


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	3.46	3.68	3.07




OIL ANALYSIS REPORT


Particle Trend




Water




Viscosity @ 100°C



Water




Viscosity @ 100°C








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	61.6	62.5	66.9
Visc @ 100°C	cSt	ASTM D445	10.6	10.7	11.5
Viscosity Index (VI)	Scale	ASTM D2270	162	162	167

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0843187 **Received** : 24 Aug 2023
Lab Number : 05934314 **Diagnosed** : 31 Aug 2023
Unique Number : 10619585 **Diagnostician** : Doug Bogart
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)