


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



KAESER SM 15 7091777 (S/N 1237)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2020 No	2020 May2021 Jul2021	Jan2022 May2022 Sep2022 Jan202	3 Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004304	KCP52998	KCP49048
Sample Date		Client Info		14 Aug 2023	13 Jan 2023	21 Sep 2022
Machine Age	hrs	Client Info		28841	24181	21648
Oil Age	hrs	Client Info		0	2533	3458
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	7	3	3
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	<1	51	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	50	77	76
Calcium	ppm	ASTM D5185m	2	<1	2	0
Phosphorus	ppm	ASTM D5185m		3	10	34
Zinc	ppm	ASTM D5185m		0	1	0
Sulfur	ppm	ASTM D5185m		18993	18853	22738
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	<1	2
Sodium	ppm	ASTM D5185m		13	9	8
Potassium	ppm	ASTM D5185m	>20	3	2	2
Water	%	ASTM D6304	>0.05	0.012	0.022	0.023
ppm Water	ppm	ASTM D6304	>500	124.1	220.4	232.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1101	67603	4655
Particles >6µm		ASTM D7647	>1300	307	<u>^</u> 21145	<u>▲</u> 1526
Particles >14µm		ASTM D7647	>80	25	<u>▲</u> 1392	▲ 122
Particles >21µm		ASTM D7647	>20	6	△ 337	<u>▲</u> 26
Particles >38μm		ASTM D7647	>4	0	<u> </u>	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	<u>\$\rightarrow\$ 23/22/18</u>	▲ 19/18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Asid Number (ANI)	I/OLI/-	ACTM DODAE	0.4	0.07	0.01	0.05

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.31

0.27

0.35



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

: 05934347 : 10619618

Diagnosed

: 28 Aug 2023 Diagnostician : Jonathan Hester Test Package : IND 2 (Additional Tests: KF, PrtCount)

FORT WORTH, TX US 76177

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: