

# **OIL ANALYSIS REPORT**

Sample Rating Trend



#### Area [41007666] Machine Id DVT 9 Component Pump Fluid

# Fluid NOT GIVEN (--- GAL)

#### DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the brand and viscosity of the oil on your next sample.

## Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP245172	USP242021	
Sample Date		Client Info		19 Aug 2023	17 May 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	
Chromium	ppm	ASTM D5185m	>2	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	0	
Lead	ppm	ASTM D5185m	>2	0	0	
Copper	ppm	ASTM D5185m	>8	0	0	
Tin	ppm	ASTM D5185m	>4	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		13	0	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		30	51	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	2	
Water	%	ASTM D6304	>0.01	0.001	▲ 0.061	
ppm Water	ppm	ASTM D6304	>100	0.00	<b>6</b> 10	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	2507		
Particles >6µm		ASTM D7647	>2500	777		
Particles >14µm		ASTM D7647	>320	58		
Particles >21µm		ASTM D7647	>80	10		
Particles >38µm		ASTM D7647	>20	0		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.059	0.013	

Contact/Location: Service Manager - HILDAL



/av1

0.08

0.08 Jape∧0.04

0.00

100

60 40

20 Mav17/2

12

Ê<sup>10)</sup>

6

4)

21

0

articles (1 8

(40°C) 8 cSt(

Water

Severe 0.02


Abnormal


Viscosity @ 40°C

Particle Trend

# **OIL ANALYSIS REPORT**

scalar





NONE

NONE

NONE

Laboratory

Sample No.

Certificate L2367

Contact/Location: Service Manager - HILDAL