





Machine Id  
**FRICK FRICK B**  
Component  
**Screw Compressor**  
Fluid  
**ISO 100 (--- GAL)**




## COMPONENT CONDITION SUMMARY

### ▲ Water



### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.1	▲ <b>0.396</b>	▲ 0.442	▲ 0.477
ppm Water	ppm	ASTM D6304	>1000	▲ <b>3962.9</b>	▲ 4428.5	▲ 4770
Particles >4µm		ASTM D7647	>10000	▲ <b>11376</b>	3566	5649
Particles >6µm		ASTM D7647	>2500	▲ <b>3168</b>	828	1452
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ <b>21/19/15</b>	19/17/13	20/18/14

Customer Id: GARROW  
Sample No.: TO60000867  
Lab Number: 05934407  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS

### 03 Jul 2023 Diag: Don Baldrige

#### WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 06 Jun 2023 Diag: Jonathan Hester

#### WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 11 May 2023 Diag: Doug Bogart

#### WATER




We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



Machine Id  
**FRICK FRICK B**  
Component  
**Screw Compressor**  
Fluid  
**ISO 100 (--- GAL)**



**DIAGNOSIS**

**Recommendation**  
We recommend you service the filters on this component. Resample at the next service interval to monitor.

**Wear**  
All component wear rates are normal.

**Contamination**  
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

**Fluid Condition**  
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO60000867</b>	TO60000857	TO60000859
Sample Date	Client Info		<b>02 Aug 2023</b>	03 Jul 2023	06 Jun 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >60	<b>&lt;1</b>	0	<1
Chromium	ppm	ASTM D5185m >4	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	<b>0</b>	0	1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m >5	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >30	<b>0</b>	0	0
Tin	ppm	ASTM D5185m >15	<b>0</b>	<1	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m	<b>0</b>	0	<1
Calcium	ppm	ASTM D5185m	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>14</b>	13	24
Zinc	ppm	ASTM D5185m	<b>0</b>	0	0
Sulfur	ppm	ASTM D5185m	<b>1737</b>	1870	2815


CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>24</b>	24	20
Sodium	ppm	ASTM D5185m	<b>1</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	4
Water	%	ASTM D6304 >0.1	<b>▲ 0.396</b>	▲ 0.442	▲ 0.477
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 3962.9</b>	▲ 4428.5	▲ 4770

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 11376</b>	3566	5649
Particles >6µm	ASTM D7647	>2500	<b>▲ 3168</b>	828	1452
Particles >14µm	ASTM D7647	>320	<b>255</b>	53	83
Particles >21µm	ASTM D7647	>80	<b>55</b>	13	16
Particles >38µm	ASTM D7647	>20	<b>1</b>	0	1
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>▲ 21/19/15</b>	19/17/13	20/18/14


FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.893</b>	0.192	0.91

# OIL ANALYSIS REPORT


## ▲ Water




## ▲ Particle Trend




## ▲ Viscosity @ 100°C



## ▲ Acid Number




## ▲ Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	109	110
Visc @ 100°C	cSt	ASTM D445	11.5	18.8	19.1
Viscosity Index (VI)	Scale	ASTM D2270	102	193	195

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### ▲ Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO60000867 **Received** : 24 Aug 2023  
**Lab Number** : 05934407 **Diagnosed** : 29 Aug 2023  
**Unique Number** : 10619678 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**GARLAND RENEWABLES**  
 3175 ELM GROVE RD  
 ROWLETT, TX  
 US 75089  
 Contact: DUSTIN FRY  
 dustin@morrowrenew.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: