




# PROBLEM SUMMARY

Sample Rating Trend




**WATER**



Machine Id  
**MCQUAY QBE CHILLER 3 STAGE 2 (S/N STNU121200121)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**POE (6 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Water



## RECOMMENDATION

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.02	▲ <b>0.089</b>	▲ 0.118	▲ 0.132
ppm Water	ppm	ASTM D6304	>250	▲ <b>896.5</b>	▲ 1187.7	▲ 1325.0

Customer Id: NORDEF  
 Sample No.: WC0709616  
 Lab Number: 05934412  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 04 Aug 2022 Diag: Doug Bogart

#### WATER



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. All component wear rates are normal. Insufficient sample was received to conduct all the routine laboratory tests. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

[view report](#)



### 26 Jul 2021 Diag: Don Baldrige

#### WATER



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate concentration of water present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 22 Aug 2019 Diag: Don Baldrige

#### WATER



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**MCQUAY QBE CHILLER 3 STAGE 2 (S/N STNU121200121)**

Component  
**Refrigeration Compressor**  
Fluid  
**POE (6 GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a light concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0709616</b>	WC0578137	WCI2245801
Sample Date	Client Info		<b>19 Jul 2023</b>	04 Aug 2022	26 Jul 2021
Machine Age	yrs	Client Info	<b>11</b>	10	9
Oil Age	yrs	Client Info	<b>1</b>	10	9
Oil Changed	Client Info		<b>Not Changed</b>	Not Changed	Not Changed
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	<b>0</b>	3	1
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >50	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >2	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >100	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m >4	<b>0</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	0	0
Calcium	ppm	ASTM D5185m	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>3</b>	6	13
Zinc	ppm	ASTM D5185m	<b>0</b>	0	0
Sulfur	ppm	ASTM D5185m	<b>0</b>	1	7

## CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>16</b>	46	▲ 54
Sodium	ppm	ASTM D5185m	<b>0</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	0
Water	%	ASTM D6304 >0.02	▲ <b>0.089</b>	▲ 0.118	▲ 0.132
ppm Water	ppm	ASTM D6304 >250	▲ <b>896.5</b>	▲ 1187.7	▲ 1325.0

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	<b>0.014</b>	---	0.016




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.02	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>54.8</b>	50.0	61.6

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0709616 **Received** : 24 Aug 2023  
**Lab Number** : **05934412** **Diagnosed** : 29 Aug 2023  
**Unique Number** : 10619683 **Diagnostician** : Angela Borella  
**Test Package** : IND 2

**NORTH AMERICAN MECHANICAL**  
 4401 STATE RD 19  
 WINDSOR, WI  
 US 53598  
 Contact: STACEY QUAM  
 squam@naminc.com  
 T: (608)240-8906  
 F: (608)240-8965

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)