




# PROBLEM SUMMARY

## Sample Rating Trend

ISO




Area  
**RP-107 [23432102]**  
 Machine Id  
**B68818 - AUGER HAARSLEV HAMMER MILL #1 FEED SCREW B68818**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 320 (--- GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

| Sample Status   |                        | ATTENTION  | ABNORMAL   | NORMAL   |
|-----------------|------------------------|------------|------------|----------|
| Particles >4µm  | ASTM D7647 >10000      | ▲ 15684    | ▲ 30369    | 4037     |
| Oil Cleanliness | ISO 4406 (c) >20/18/15 | ▲ 21/18/13 | ▲ 22/20/17 | 19/17/12 |

Customer Id: HORAUS  
 Sample No.: WC0826202  
 Lab Number: 05934876  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

| Action               | Status | Date | Done By | Description  |
|----------------------|--------|------|---------|--|
| Change Filter        | ---    | ---  | ?       | We recommend you service the filters on this component.  |
| Information Required | ---    | ---  | ?       | NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. |

## HISTORICAL DIAGNOSIS

### 21 May 2023 Diag: Wes Davis

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 14 Feb 2023 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 29 Nov 2022 Diag: Wes Davis

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**RP-107 [23432102]**  
 Machine Id  
**B68818 - AUGER HAARSLEV HAMMER MILL #1 FEED SCREW B68818**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 320 (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

|               | method      | limit/base  | current            | history1    | history2    |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info |             | <b>WC0826202</b>   | WC0799665   | WC0765455   |
| Sample Date   | Client Info |             | <b>20 Aug 2023</b> | 21 May 2023 | 14 Feb 2023 |
| Machine Age   | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Age       | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Changed   | Client Info |             | <b>Not Chngd</b>   | N/A         | N/A         |
| Sample Status |             |             | <b>ATTENTION</b>   | ABNORMAL    | NORMAL      |

## WEAR METALS

|          | method | limit/base  | current | history1     | history2 |   |
|----------|--------|-------------|---------|--------------|----------|---|
| Iron     | ppm    | ASTM D5185m | >200    | <b>2</b>     | 2        | 1 |
| Chromium | ppm    | ASTM D5185m | >15     | <b>0</b>     | 0        | 0 |
| Nickel   | ppm    | ASTM D5185m | >15     | <b>0</b>     | <1       | 0 |
| Titanium | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0 |
| Silver   | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0 |
| Aluminum | ppm    | ASTM D5185m | >25     | <b>0</b>     | 0        | 0 |
| Lead     | ppm    | ASTM D5185m | >100    | <b>0</b>     | 0        | 0 |
| Copper   | ppm    | ASTM D5185m | >200    | <b>&lt;1</b> | 0        | 0 |
| Tin      | ppm    | ASTM D5185m | >25     | <b>0</b>     | 0        | 0 |
| Vanadium | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0 |
| Cadmium  | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0 |

## ADDITIVES

|            | method | limit/base  | current | history1     | history2 |      |
|------------|--------|-------------|---------|--------------|----------|------|
| Boron      | ppm    | ASTM D5185m | 33      | <b>29</b>    | 32       | 25   |
| Barium     | ppm    | ASTM D5185m | 5       | <b>&lt;1</b> | 0        | 0    |
| Molybdenum | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0    |
| Manganese  | ppm    | ASTM D5185m |         | <b>0</b>     | <1       | 0    |
| Magnesium  | ppm    | ASTM D5185m | 5       | <b>&lt;1</b> | 0        | 0    |
| Calcium    | ppm    | ASTM D5185m | 5       | <b>6</b>     | 2        | <1   |
| Phosphorus | ppm    | ASTM D5185m | 437     | <b>399</b>   | 445      | 425  |
| Zinc       | ppm    | ASTM D5185m | 5       | <b>3</b>     | 0        | 1    |
| Sulfur     | ppm    | ASTM D5185m | 5000    | <b>5810</b>  | 6898     | 6491 |

## CONTAMINANTS

|           | method | limit/base  | current | history1     | history2 |   |
|-----------|--------|-------------|---------|--------------|----------|---|
| Silicon   | ppm    | ASTM D5185m | >50     | <b>0</b>     | 0        | 6 |
| Sodium    | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0 |
| Potassium | ppm    | ASTM D5185m | >20     | <b>&lt;1</b> | 1        | 0 |

## FLUID CLEANLINESS

|                 | method       | limit/base | current           | history1   | history2 |
|-----------------|--------------|------------|-------------------|------------|----------|
| Particles >4µm  | ASTM D7647   | >10000     | <b>▲ 15684</b>    | ▲ 30369    | 4037     |
| Particles >6µm  | ASTM D7647   | >2500      | <b>1554</b>       | ▲ 9071     | 687      |
| Particles >14µm | ASTM D7647   | >320       | <b>78</b>         | ▲ 937      | 40       |
| Particles >21µm | ASTM D7647   | >80        | <b>28</b>         | ▲ 288      | 13       |
| Particles >38µm | ASTM D7647   | >20        | <b>3</b>          | 10         | 1        |
| Particles >71µm | ASTM D7647   | >4         | <b>1</b>          | 0          | 0        |
| Oil Cleanliness | ISO 4406 (c) | >20/18/15  | <b>▲ 21/18/13</b> | ▲ 22/20/17 | 19/17/12 |


## FLUID DEGRADATION

|                  | method   | limit/base | current | history1    | history2 |      |
|------------------|----------|------------|---------|-------------|----------|------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.7     | <b>0.94</b> | 0.97     | 0.85 |




# OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number



Viscosity @ 40°C




| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | LIGHT    |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | NONE     | NONE     |
| Debris           | scalar | *Visual    | NONE    | NONE     | NONE     |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | NORML    | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >0.2    | NEG      | NEG      |
| Free Water       | scalar | *Visual    |         | NEG      | NEG      |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C      | cSt    | ASTM D445  | 323     | 324      | 322      |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|


Color




Bottom

## GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0826202 Received : 25 Aug 2023  
 Lab Number : 05934876 Diagnosed : 28 Aug 2023  
 Unique Number : 10620147 Diagnostician : Wes Davis  
 Test Package : IND 2 ( Additional Tests: PrtCount )

**HORMEL FOODS - AUSTIN**  
 1101 NORTH MAIN ST  
 AUSTIN, MN  
 US 55912  
 Contact: RYAN LOWE  
 rslowe@hormel.com  
 T: (507)437-5674  
 F: (507)437-9805

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)