


# PROBLEM SUMMARY

## Sample Rating Trend


## ADDITIVES

Area  
**076 G1 [2697536]**  
Machine Id  
**B-9002 Blower (S/N LR97-639)**  
Component  
**Blower**  
Fluid  
**SHELL CORENA P 100 (12 GAL)**




## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



### ▲ Additives



## RECOMMENDATION

Confirm oil reference for machine. No other action required at this time. Resample at next normal interval.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Calcium	ppm	ASTM D5185m	60	▲ 6	▲ 3	▲ 0
Zinc	ppm	ASTM D5185m	190	▲ 3	▲ 12	▲ 0
Sulfur	ppm	ASTM D5185m	1300	▲ 50	▲ 27	▲ 120
Particles >4µm		ASTM D7647	>2500	▲ 8962	4564	5808
Particles >6µm		ASTM D7647	>640	▲ 1730	1501	601
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 20/18/14	19/18/15	20/16/12

Customer Id: HEXGEI  
Sample No.: PLS0000670  
Lab Number: 05935314  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Mike Johnson +1 (615)771-6030  
[mike.johnson@amrri.com](mailto:mike.johnson@amrri.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 14 Feb 2023 Diag: Mike Johnson

#### ADDITIVES



Confirm oil reference for machine. No other action required at this time. Resample at next normal interval. Wear particles are low and acceptable. Contamination is on par with new unfiltered oil. Fluid health indicators do not match the reference oil, but are steady compared to previous samples.

view report



### 24 Feb 2021 Diag: Mike Johnson

#### ADDITIVES



Sample at next normal interval. The wear debris levels in this sample are low and appropriate. The PQ value, which reflects larger ferromagnetic particles, is slightly elevated. There is no indication of lubricant health problems in this sample. The fluid is acceptable for continued use. There is no indication of lubricant health problems in this sample. The fluid is acceptable for continued use. Without a reference sample it is particularly difficult to make a judgement call about the relative health of the fluid.

view report



### 30 Sep 2020 Diag: Mike Johnson

#### ADDITIVES




No other corrective actions. Sample at the regular interval. Wear rate is low and steady. Particulate levels are typical for new oil from the drum. Filter is possible. Additive levels are not consistent with Corena P 100 fluid, but additives levels are steady, and the fluid properties suggest the oil is acceptable for continued use.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



## ADDITIVES



Area  
**076 G1 [2697536]**  
Machine Id  
**B-9002 Blower (S/N LR97-639)**  
Component  
**Blower**  
Fluid  
**SHELL CORENA P 100 (12 GAL)**

### DIAGNOSIS

#### Recommendation

Confirm oil reference for machine. No other action required at this time. Resample at next normal interval.

#### Wear

Wear particles are low and acceptable.

#### Contamination

Contamination is on par with new unfiltered oil. Filtration can help extend machine life.

#### Fluid Condition

Fluid health indicators do not match the reference oil, but are steady compared to previous samples.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PLS0000670</b>	PLS0000547	PLS0000326
Sample Date	Client Info		<b>01 Aug 2023</b>	14 Feb 2023	24 Feb 2021
Machine Age	yrs	Client Info	<b>3</b>	4	0
Oil Age	yrs	Client Info	<b>1</b>	1	8
Oil Changed	Client Info		<b>Not Changed</b>	Changed	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>24</b>	21	29
Iron	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	2
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >20	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	1
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	1
Barium	ppm	ASTM D5185m 0	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	0	<1
Calcium	ppm	ASTM D5185m 60	<b>▲ 6</b>	▲ 3	▲ 0
Phosphorus	ppm	ASTM D5185m 0	<b>97</b>	95	▲ 87
Zinc	ppm	ASTM D5185m 190	<b>▲ 3</b>	▲ 12	▲ 0
Sulfur	ppm	ASTM D5185m 1300	<b>▲ 50</b>	▲ 27	▲ 120






### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185m	<b>1</b>	<1	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	0

### INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0.2	0.2
Nitration	Abs/cm	*ASTM D7624	<b>16.5</b>	16.0	16.5
Sulfation	Abs/.1mm	*ASTM D7415	<b>153.7</b>	139.6	160.8

# OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 8962	4564	5808
Particles >6µm	ASTM D7647	>640	▲ 1730	1501	601
Particles >14µm	ASTM D7647	>80	109	192	26
Particles >21µm	ASTM D7647	>20	31	58	7
Particles >38µm	ASTM D7647	>4	1	2	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/18/14	19/18/15	20/16/12

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414		201.8	196.4	207.9
Acid Number (AN)	mg KOH/g ASTM D8045	0.3	0.56	0.38	0.383

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual		NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	100	102	102	99.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000670  
**Lab Number** : 05935314  
**Unique Number** : 10620585  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ, PrtCount )

**HEXION INC - GONZALES PLANT**  
 4338 HWY 73  
 GEISMAR, LA  
 US 70734

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: Shannon Ourso  
 shannon.ourso@hexion.com;mike.johnson@amrri.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: