


REACTOR 5

# **PROBLEM SUMMARY**


# R5 AGITATOR - 10123132 (S/N 20030-C)

Gearbox

MOBIL SHC 630 (4 QTS)



# **COMPONENT CONDITION SUMMARY**



# RECOMMENDATION

Filter the oil per the notes below. Lubricant is dirty, but improved, and otherwise acceptable for continued use.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	SEVERE	SEVERE				
Particles >4μm	ASTM D7647 >	>20000	<b>4695</b>	225298	196067				
Particles >6μm	ASTM D7647 >	>5000	<b>^</b> 7007	88398	42978				
Oil Cleanliness	ISO 4406 (c) >	>21/19/16	<u>23/20/15</u>	<b>25/24/17</b>	<b>25/23/15</b>				

Customer Id: HEXSPROR Sample No.: PLSI2295488 Lab Number: 05935316 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Mike Johnson +1 (615)771-6030 mike.johnson@amrri.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 16 Feb 2018 Diag: Doug Bogart

×

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. The oil change at the time of sampling has been noted. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. The fluid was specified as MOBIL SHC 629, however, a fluid match indicates that this fluid is ISO 220 Synthetic (PAG) Gear Oil. Please confirm the oil type and grade on your next sample.All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are notably high. Viscosity of sample indicates oil is within ISO 220 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



## 16 Oct 2017 Diag:





Filter the oil per the notes below. Lubricant is dirty, but otherwise acceptable for continued uese. Wear rates are low and appropraite. Expect to see some increase unless the solid particulate is brought under control. Particles >6µm are severely high. Particles >4µm are severely high. Calcium ppm levels are notably low. Phosphorus ppm levels are notably low. Sulfur ppm levels are notably low. Zinc ppm levels are notably low. Please verify that topups are being conducted with the PAO lubricant, SHC 629, as noted for this drive.



## 18 May 2017 Diag:

ISO



These samples where not purchased through AMRRI/Fluid Forensics. For Fluid Forensics analysis on future samples please order bottles through AMRRI. 615.513.3000.This oil should be filtered extensively. Oil health appears acceptable. Wear debris is low and appropriate. However, assuming the sample was NOT collected at a drain port or with a drop tube, the oils is substantially dirty. Simply changing the oil will NOT address contamination levels of this magnitude. The wear debris results are low and appropriate for this type of machine. Particles >4 $\mu$ m are severely high. Oil Cleanliness is severe. Particles >71 $\mu$ m are abnormally high. Particles >14 $\mu$ m are abnormally high. Particles >21 $\mu$ m are abnormally high. Particles >38 $\mu$ m are notably high. The fluid health is acceptable.






# **OIL ANALYSIS REPORT**

# REACTOR 5 R5 AGITATOR - 10123132 (S/N 20030-C)

Gearbox

MOBIL SHC 630 (4 QTS)





# **DIAGNOSIS**

# Recommendation

Filter the oil per the notes below. Lubricant is dirty, but improved, and otherwise acceptable for continued use.

Wear rates are low and appropraite. Expect to see some increase unless the solid particulate is brought under control.

## Contamination

Particles >6µm are high. Particles >4µm are high.

## **Fluid Condition**

Calcium ppm levels are notably low. Phosphorus ppm levels are notably low. Sulfur ppm levels are notably low. Zinc ppm levels are notably low. Please verify that top-ups are being conducted with the PAO lubricant, SHC 630, as noted for this drive.

		May201	/ Oct2017	Feb2018 Au	g2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PLSI2295488	PLSI2275786	PLSI2275785
Sample Date		Client Info		15 Aug 2023	16 Feb 2018	16 Oct 2017
Machine Age	yrs	Client Info		35	20	25
Oil Age	yrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	N/A
Sample Status				ABNORMAL	SEVERE	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		16	23	19
Iron	ppm	ASTM D5185m	>200	3	12	6
Chromium	ppm	ASTM D5185m	>15	0	<1	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>100	0	<1	0
Copper	ppm	ASTM D5185m	>200	0	<1	<1
Tin	ppm	ASTM D5185m	>25	0	0	2
Antimony	ppm	ASTM D5185m	>5		0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	0	2
Calcium	ppm	ASTM D5185m		0	<u>^</u> 2	<u>^</u> 2
Phosphorus	ppm	ASTM D5185m		513	<b>▲</b> 372	<u>426</u>
Zinc	ppm	ASTM D5185m		0	<u></u> <1	<u> 5</u>
Sulfur	ppm	ASTM D5185m		24	<u> </u>	<u> </u>
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	18	20	28
Sodium	ppm	ASTM D5185m		<1	2	<1
Potassium	ppm	ASTM D5185m	>20	0	2	<1
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624		4.6	4.	5.
Sulfation	Abs/.1mm	*ASTM D7415		12.2	8.	13.



# OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number

**Unique Number** : 10620587 Test Package

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 25 Aug 2023 : PLSI2295488 : 05935316

Diagnosed : 28 Aug 2023 Diagnostician : Mike Johnson

: IND 2 ( Additional Tests: FT-IR, PQ, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**HEXION INC - SPRINGFIELD PLANT** 

470 S SECOND ST SPRINGFIELD, OR US 97477

Contact: TOM CURTIS

thomas.curtis@hexion.com;mike.johnson@amrri.com

T: F: