

## **OIL ANALYSIS REPORT**

# CHELIN

# CHAD STEELE Machine Id 19-064S13-1

Component **Hydraulic System** 

NOT GIVEN (--- QTS)



Sample Rating Trend



#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

#### Wear

The copper level is abnormal. All other component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2023	Aug <sup>2</sup> 023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0703253	WC0837692	
Sample Date		Client Info		24 Aug 2023	31 Jul 2023	
Machine Age	hrs	Client Info		168	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>10	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>75	<u> </u>	0	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		<1	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		75	90	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	3	
Calcium	ppm	ASTM D5185m		389	368	
Phosphorus	ppm	ASTM D5185m		356	340	
Zinc	ppm	ASTM D5185m		0	2	
Sulfur	ppm	ASTM D5185m		1302	1648	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	<1	4	
Sodium	ppm	ASTM D5185m		1	<1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.1	0.022	0.024	
ppm Water	ppm	ASTM D6304	>1000	221.4	242.3	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	1323	3379	
Particles >6µm		ASTM D7647	>1300	240	647	
Particles >14µm		ASTM D7647	>160	28	16	
Particles >21µm		ASTM D7647	>40	6	3	
Particles >38µm		ASTM D7647	>10	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	18/15/12	19/17/11	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.142	1.07	



### **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** 

: WC0703253 : 05935377 : 10620648

Received

Diagnosed

: 25 Aug 2023 : 03 Sep 2023 Diagnostician : Doug Bogart

Test Package : MOB 2 ( Additional Tests: KF, KV100, VI ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

500 WHITE PLAINS RD TARRYTOWN, NY US 10591

Contact: PATTI CUSATIS patti.cusatis@basf.com T: (914)785-2970

Contact/Location: PATTI CUSATIS - BASTAR

F: (914)785-2166