


PROBLEM SUMMARY

Area [128208]

KAESER BSD 50 5667465 (S/N 1569)


Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status			ATTENTION	NORMAL	ABNORMAL	
Particles >14μm	ASTM D7647	>80	<u> </u>	23	<u></u> 154	
Particles >21μm	ASTM D7647	>20	25	7	<u> </u>	
Oil Cleanliness	ISO 4406 (c)	>17/13	17/14	16/12	△ 19/14	

Customer Id: TRECLE Sample No.: KC70858 Lab Number: 05935388 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

17 Oct 2022 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Apr 2020 Diag: Don Baldridge

150



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



22 Aug 2019 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

[128208]

KAESER BSD 50 5667465 (S/N 1569)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC70858	KC107948	KC64313
Sample Date		Client Info		12 Aug 2023	17 Oct 2022	01 Apr 2020
Machine Age	hrs	Client Info		55335	49319	27373
Oil Age	hrs	Client Info		11988	5972	5202
Oil Changed		Client Info		Changed	Not Changd	Not Changd
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	1	1
Lead	ppm	ASTM D5185m	>10	0	1	<1
Copper	ppm	ASTM D5185m	>50	3	0	<1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				2
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
			III III DAGC			
Boron	ppm	ASTM D5185m	00	0	0	9
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0	0 <1	0 <1
Manganese	ppm	ASTM D5185m ASTM D5185m	90	0	<1	12
Magnesium Calcium	ppm	ASTM D5185m		0	0	0
	ppm	ASTM D5185m	2	0	17	<1
Phosphorus Zinc	ppm	ASTM D5185m		0	0	2
	ppm	ASTIVI DOTOSITI		U	0	2
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	1
Sodium	ppm	ASTM D5185m		2	<1	1
Potassium	ppm	ASTM D5185m	>20	0	3	0
Water	%	ASTM D6304	>0.05	0.007	0.009	0.006
ppm Water	ppm	ASTM D6304	>500	70.9	97.2	65.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2924	2503	14828
Particles >6µm		ASTM D7647	>1300	1041	406	<u>▲</u> 3750
Particles >14µm		ASTM D7647	>80	<u> 102</u>	23	<u> </u>
Particles >21µm		ASTM D7647	>20	<u>^</u> 25	7	<u>▲</u> 27
Particles >38μm		ASTM D7647	>4	1	0	3
Particles >71µm		ASTM D7647		0	0	2
Oil Cleanliness		ISO 4406 (c)	>17/13	△ 17/14	16/12	<u></u> 19/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.40	0.448



OIL ANALYSIS REPORT





Certificate L2367

Lab Number **Unique Number** Test Package

: 05935388

: 10620659 : IND 2

Diagnosed Diagnostician

: 28 Aug 2023 : Don Baldridge CLEVELAND, OH US 44127

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: