


PROBLEM SUMMARY

Sample Rating Trend

DIRT




Area
HAPL
Machine Id
HAPL 3.4 BRIDLE NO.3 W/ DEFLECTOR ROLL (S/N 16-1100-0415)
Component
Gearbox
Fluid
ISO 320 (--- QTS)




COMPONENT CONDITION SUMMARY


▲ Ferrous Alloys



▲ Silicon (ppm)



▲ Viscosity @ 40°C



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ABNORMAL | NORMAL | NORMAL |
|---------------|-----|-------------|------|----------|--------|--------|
| Iron | ppm | ASTM D5185m | >200 | ▲ 193 | 8 | 6 |
| Silicon | ppm | ASTM D5185m | >50 | ▲ 56 | 2 | 3 |
| Visc @ 40°C | cSt | ASTM D445 | 320 | ▲ 212 | 333 | 333 |

Customer Id: OUTCALAL
Sample No.: RP0035389
Lab Number: 05935558
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Apr 2023 Diag: Wes Davis

NORMAL



Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



15 Jul 2022 Diag: Wes Davis

NORMAL



Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



13 Jan 2022 Diag: Wes Davis

NORMAL



Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Area
HAPL
 Machine Id
HAPL 3.4 BRIDLE NO.3 W/ DEFLECTOR ROLL (S/N 16-1100-0415)
 Component
Gearbox
 Fluid
ISO 320 (--- QTS)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

▲ Wear

The iron level is marginal. All other component wear rates are normal.

▲ Contamination

Elemental level of silicon (Si) above normal.

▲ Fluid Condition

Viscosity of sample indicates oil is within ISO 220 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | RP0035389 | RP0034534 | RP0028816 |
| Sample Date | Client Info | | 24 Aug 2023 | 07 Apr 2023 | 15 Jul 2022 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ABNORMAL | NORMAL | NORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|------------|------------------|--------------|----------|----------|
| PQ | ASTM D8184 | | 116 | 12 | 20 |
| Iron | ppm | ASTM D5185m >200 | ▲ 193 | 8 | 6 |
| Chromium | ppm | ASTM D5185m >15 | 5 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >15 | 2 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | 1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m >25 | 9 | 0 | <1 |
| Lead | ppm | ASTM D5185m >100 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m >200 | <1 | 0 | <1 |
| Tin | ppm | ASTM D5185m >25 | 0 | 0 | <1 |
| Antimony | ppm | ASTM D5185m >5 | --- | --- | --- |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 8 | 7 | 6 |
| Barium | ppm | ASTM D5185m | 1 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | <1 | <1 | 0 |
| Manganese | ppm | ASTM D5185m | 2 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | 4 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | 9 | 30 | 19 |
| Phosphorus | ppm | ASTM D5185m | 173 | 100 | 81 |
| Zinc | ppm | ASTM D5185m | 13 | 0 | 0 |






CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >50 | ▲ 56 | 2 | 3 |
| Sodium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Potassium | ppm | ASTM D5185m >20 | 1 | 4 | <1 |
| Water | % | ASTM D6304 >0.2 | 0.003 | 0.006 | 0.024 |
| ppm Water | ppm | ASTM D6304 >2000 | 26.3 | 62.7 | 246.5 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.48 | 0.28 | 0.35 |

OIL ANALYSIS REPORT




| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.2 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|---------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 320 | ▲ 212 | 333 | 333 |






| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

Color



Bottom

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0035389 **Received** : 25 Aug 2023
Lab Number : 05935558 **Diagnosed** : 28 Aug 2023
Unique Number : 10620829 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: PQ)

OUTOKUMPU STAINLESS USA
 HWY 43 N
 CALVERT, AL
 US 36513
 Contact: MARIO JOHNSON
 Mario.johnson@outokumpu.com
 T: (251)321-4105
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)