FUEL REPORT

Sample Rating Trend

ISO

Machine Id
KIOTI NX6010HST TL6000098
Component
Diesel Fuel
Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KT0000682**	---	---
Sample Date		Client Info		**17 Aug 2023**	---	---
Machine Age	hrs	Client Info		**562**	---	---
Sample Status				**ATTENTION**	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		**0.845**	---	---
Fuel Color	text	*Visual Screen		**YIlow**	---	---
ASTM Color	scalar	*ASTM D1500		**1.5**	---	---
Visc @ 40°C	cSt	ASTM D445		**2.54**	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		**54**	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		**63**	---	---
Sulfur (UVF)	ppm	ASTM D5453		**15**	---	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		**146**	---	---
5% Distillation Point	°C	ASTM D86		**187**	---	---
10% Distill Point	°C	ASTM D86		**201**	---	---
15% Distillation Point	°C	ASTM D86		**213**	---	---
20% Distill Point	°C	ASTM D86		**220**	---	---
30% Distill Point	°C	ASTM D86		**235**	---	---
40% Distill Point	°C	ASTM D86		**248**	---	---
50% Distill Point	°C	ASTM D86		**262**	---	---
60% Distill Point	°C	ASTM D86		**276**	---	---
70% Distill Point	°C	ASTM D86		**291**	---	---
80% Distill Point	°C	ASTM D86		**307**	---	---
85% Distillation Point	°C	ASTM D86		**316**	---	---
90% Distill Point	°C	ASTM D86		**3237**	---	---
95% Distillation Point	°C	ASTM D86		**344**	---	---
Final Boiling Point	°C	ASTM D86		**351**	---	---
Distillation Residue	%	ASTM D86		**1.4**	---	---
Distillation Loss	%	ASTM D86		**0.9**	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		**36.0**	---	---
Cetane Index		ASTM D4737	<40.0	**47.0**	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	**3**	---	---
Sodium	ppm	ASTM D5185m	<0.1	**0**	---	---
Potassium	ppm	ASTM D5185m	<0.1	**<1**	---	---
Water	%	ASTM D6304	<0.05	**0.008**	---	---
ppm Water	ppm	ASTM D6304	<500	**80.3**	---	---
% Gasoline	%	*In-House	<0.50	**0.0**	---	---
% Biodiesel	%	*In-House	<20.0	**0.0**	---	---

FUEL REPORT

Particle Count



Particle Trend



Water



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ **53782**	---	---
Particles >6µm	ASTM D7647	>640	▲ **14891**	---	---
Particles >14µm	ASTM D7647	>80	▲ **960**	---	---
Particles >21µm	ASTM D7647	>20	▲ **212**	---	---
Particles >38µm	ASTM D7647	>4	▲ **5**	---	---
Particles >71µm	ASTM D7647	>3	**0**	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ **23/21/17**	---	---

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	**0**	---	---
Nickel	ppm	ASTM D5185m	<0.1	**0**	---	---
Lead	ppm	ASTM D5185m	<0.1	**0**	---	---
Vanadium	ppm	ASTM D5185m	<0.1	**0**	---	---
Iron	ppm	ASTM D5185m	<0.1	**<1**	---	---
Calcium	ppm	ASTM D5185m	<0.1	**1**	---	---
Magnesium	ppm	ASTM D5185m	<0.1	**0**	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	**2**	---	---
Zinc	ppm	ASTM D5185m	<0.1	**0**	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				*no image*	*no image*
Bottom				*no image*	*no image*

GRAPHS

Viscosity @ 40°C



Fuel Distillation Curve



Fuel Distillation Curve



Pensky-Martens Flash Point (°C)



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KT0000682 **Received** : 25 Aug 2023
Lab Number : 05935808 **Diagnosed** : 01 Sep 2023
Unique Number : 10621079 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

VERMEER AG EAST TEXAS
1200 S LOOP 7
ATHENS, TX
US 75752
Contact: KEITH LEWIS
service@vermeerageasttexas.com
T: (903)904-4049
F: