




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER SM15 3433577 (S/N 1136)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KC05936127	KC93475	KC87252
Sample Date	Client Info			18 Aug 2023	29 Apr 2021	20 Apr 2020
Machine Age	hrs	Client Info		69681	66492	61868
Oil Age	hrs	Client Info		0	4624	4362
Oil Changed	Client Info			N/A	Changed	Changed
Sample Status				NORMAL	NORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	<1	0
Copper	ppm	ASTM D5185m	>50	1	3	2
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m		---	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	11	0
Barium	ppm	ASTM D5185m	90	47	33	38
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	80	77	91
Calcium	ppm	ASTM D5185m	2	3	2	4
Phosphorus	ppm	ASTM D5185m		3	3	0
Zinc	ppm	ASTM D5185m		6	<1	6

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	8	4
Sodium	ppm	ASTM D5185m		9	24	24
Potassium	ppm	ASTM D5185m	>20	3	4	6
Water	%	ASTM D6304	>0.05	0.030	0.027	0.019
ppm Water	ppm	ASTM D6304	>500	307.0	275.0	197.0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1248	3876	4355
Particles >6µm		ASTM D7647	>1300	435	904	1072
Particles >14µm		ASTM D7647	>80	49	68	65
Particles >21µm		ASTM D7647	>20	15	20	▲ 21
Particles >38µm		ASTM D7647	>4	1	0	▲ 11
Particles >71µm		ASTM D7647	>3	0	0	▲ 9
Oil Cleanliness		ISO 4406 (c)	>--/17/13	17/16/13	17/13	17/13

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.30	0.344	0.320


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.0	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC05936127
Lab Number : 05936127
Unique Number : 10621398
Test Package : IND 2

NEWTON TOOL & MACHINE
 119 FREEDOM SPRINGDALE RD
 NEWTON, NJ
 US 07860
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: