

# **PROBLEM SUMMARY**

Sample Rating Trend




F00512 - HSC 2-5 (S/N 3383)

**Refrigeration Compressor** 

VILTER 717 COMPRESSOR OIL ISO 68 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	ABNORMAL				
Particles >4µm	ASTM D7647	>10000	<u> </u>	3537	<u> </u>				
Particles >6µm	ASTM D7647	>1300	<b>2975</b>	888	<u>\$2864</u>				
Oil Cleanliness	ISO 4406 (c)	>20/17/14	<u>^</u> 21/19/13	19/17/12	<u>\</u> 21/19/12				

**Customer Id: HORFREWC Sample No.:** WC0664982 Lab Number: 05936174 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

## 04 May 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 01 Feb 2023 Diag: Don Baldridge

150



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 29 Nov 2022 Diag: Jonathan Hester

ISO




We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**



ISO

F00512 - HSC 2-5 (S/N 3383)

**Refrigeration Compressor** 

**VILTER 717 COMPRESSOR OIL ISO 68 (--- GAL)** 

## **DIAGNOSIS**

## Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		Nov202	2 Feb 2023	May2023 Ar	192023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0664982	WC0732418	WC0774947
Sample Date		Client Info		11 Aug 2023	04 May 2023	01 Feb 2023
Machine Age	hrs	Client Info		3814	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	0	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	0	0	<1
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	0	2
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m		0	0	0
CONTAMINANTS	<b>,</b>	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	1	<1
Water	%	ASTM D6304	>0.01	0.002	0.001	0.003
ppm Water	ppm	ASTM D6304	>100	16.9	12.7	28.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	<b>13457</b>	3537	<u>▲</u> 13222
Particles >6µm		ASTM D7647	>1300	<b>2975</b>	888	<u>\$\times\$ 2864</u>
Particles >14μm		ASTM D7647	>160	50	28	33
Particles >21µm		ASTM D7647	>40	10	2	5
Particles >38μm		ASTM D7647	>10	1	1	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/17/14	<u>^</u> 21/19/13	19/17/12	<u>\$\text{\Delta}\$ 21/19/12</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.2	0.016	0.016	0.015



## **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** 

: 05936174

: WC0664982 : 10621445

Received Diagnosed

: 29 Aug 2023 : Doug Bogart Diagnostician

Test Package : IND 2 ( Additional Tests: PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

900 S PLATTE AVE FREMONT, NE US 68025

Contact: JERRY SORRICK jasorrick@wholestonefarms.com

T: (402)753-3434 F: x:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)