


# **OIL ANALYSIS REPORT**

# SYN 5 **ATLAS COPCO API265534**

Compressor



### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jul2023		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH05936241		
Sample Date		Client Info		20 Jul 2023		
Machine Age	hrs	Client Info		29000		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead		ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65 >65	0		
Copper	ppm		>05	-		
Vanadium	ppm	ASTM D5185m	>10	0 <1		
	ppm	ASTM D5185m				
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		34		
Zinc	ppm	ASTM D5185m		53		
Sulfur	ppm	ASTM D5185m		104		
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	2		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.14		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
1:52:00) Ray: 1					tact/Location: 2	2 LICDETEE



## **OIL ANALYSIS REPORT**







Laboratory Sample No. Lab Number

Unique Number : 10621512

: UCH05936241 : 05936241 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 28 Aug 2023 Diagnosed : 29 Aug 2023

Diagnostician : Don Baldridge

**DETROIT AIR COMPRESSOR CO** 

FERNDALE, MI US 48220 Contact:

F: (248)544-2027

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ? ? - UCDETFER

T: