




OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Machine Id
4EK05286
 Component
Biogas Engine
 Fluid
MAHLER Q8 40WT (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for data entry updates. (Customer Sample Comment: Sample at failure)

Wear

All component wear rates are normal.

▲ Contamination

Elemental level of silicon (Si) above normal.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0660878	WC0660882	WC0660874
Sample Date	Client Info		24 Aug 2023	12 Jun 2023	12 May 2023
Machine Age	hrs	Client Info	80424	78899	78820
Oil Age	hrs	Client Info	187	124	159
Oil Changed	Client Info		Changed	N/A	N/A
Sample Status			ABNORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>45	27	11	6
Chromium	ppm	ASTM D5185m	>2	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	<1	<1
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	4	4	3
Lead	ppm	ASTM D5185m	>5	2	2	<1
Copper	ppm	ASTM D5185m	>14	7	5	3
Tin	ppm	ASTM D5185m	>13	3	3	2
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		<1	1	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		9	7	8
Calcium	ppm	ASTM D5185m		2361	2265	2522
Phosphorus	ppm	ASTM D5185m		421	364	420
Zinc	ppm	ASTM D5185m		476	460	530
Sulfur	ppm	ASTM D5185m		4412	4551	4702

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>200	▲ 200	197	147
Sodium	ppm	ASTM D5185m		1	0	1
Potassium	ppm	ASTM D5185m	>20	<1	3	2

INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	5.7	6.1	5.6
Sulfation	Abs/.1mm	*ASTM D7415	>30	18.2	20.1	19.1

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	9.0	10.4	10.1
Acid Number (AN)	mg KOH/g	ASTM D8045		0.96	0.83	1.81
Base Number (BN)	mg KOH/g	ASTM D2896		10.35	5.71	5.53











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.1	13.1	13.0

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0660878 **Received** : 28 Aug 2023
Lab Number : 05936316 **Diagnosed** : 29 Aug 2023
Unique Number : 10621587 **Diagnostician** : Doug Bogart
Test Package : MOB 2

BI-COUNTY
 3214 DOVER RD
 WOODLAWN, TN
 US 37191

Contact: KEVIN WEAVER
 kevin.weaver@cubedistrictenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)