




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**NORDBERG 5017**  
 Component  
**Circulating System**  
 Fluid  
**SHELL OMALA 68 (220 GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of visible silt present in the sample. There is a light concentration of water present in the oil. Free water present.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0749212</b>	WC0672670	WC0632088
Sample Date	Client Info		<b>23 Aug 2023</b>	06 Jun 2023	22 Apr 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>948</b>	675	399
Oil Changed	Client Info		<b>Not Changed</b>	Not Changd	Not Changed
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	<b>9</b>	8	8
Chromium	ppm	ASTM D5185m	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m	<b>3</b>	3	5
Copper	ppm	ASTM D5185m	<b>3</b>	6	1
Tin	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	5
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	3
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>0</b>	0	<1
Calcium	ppm	ASTM D5185m	<b>20</b>	75	2
Phosphorus	ppm	ASTM D5185m	<b>213</b>	312	273
Zinc	ppm	ASTM D5185m	<b>0</b>	76	11
Sulfur	ppm	ASTM D5185m	<b>10153</b>	8518	7256

## CONTAMINANTS



	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<b>1</b>	3	2
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Potassium	ppm	ASTM D5185m	<b>&gt;20</b>	0	<1
Water	%	ASTM D6304	<b>▲ 0.369</b>	---	---
ppm Water	ppm	ASTM D6304	<b>▲ 3690</b>	---	---

## VISUAL




	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>▲ HEAVY</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>▲ HAZY</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	<b>▲ 0.2%</b>	NEG	NEG	NEG
Free Water	scalar	*Visual	<b>▲ 1.0</b>	NEG	NEG	NEG











# OIL ANALYSIS REPORT



FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	68.0	<b>67.4</b>	64.3	66.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					no image
Bottom					no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0749212 **Received** : 28 Aug 2023  
**Lab Number** : 05936478 **Diagnosed** : 29 Aug 2023  
**Unique Number** : 10621749 **Diagnostician** : Don Baldrige  
**Test Package** : MOB 1 ( Additional Tests: KF )

**WAKE STONE CORPORATION-CARY**  
 222 STAR LANE  
 CARY, NC  
 US 27591  
 Contact: HUNTER BRATTON  
 hbratton@wakestonecorp.com  
 T:  
 F: (919)677-0988

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)