




# PROBLEM SUMMARY

Sample Rating Trend


ISO

Area  
**MARY K CAVARRA**  
 Machine Id  
**[MARY K CAVARRA] 010 579878-10**  
 Component  
**Steering**  
 Fluid  
**CHEVRON RANDO HDZ 68 (--- GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>2500	▲ 10591	▲ 10774	▲ 49840
Particles >6µm	ASTM D7647	>640	▲ 1210	▲ 1347	▲ 4668
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 21/17/12	▲ 21/18/13	▲ 23/19/13

Customer Id: INGPAD  
 Sample No.: MW0049542  
 Lab Number: 05936636  
 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 11 Feb 2023 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the fluid. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

view report



### 11 Aug 2021 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the fluid. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

view report



### 29 Jan 2020 Diag: Jonathan Hester

VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the fluid. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**MARY K CAVARRA**  
 Machine Id  
**[MARY K CAVARRA] 010 579878-10**  
 Component  
**Steering**  
 Fluid  
**CHEVRON RANDO HDZ 68 (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the fluid.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>MW0049542</b>	MW0049790	MW0022306
Sample Date	Client Info		<b>11 Aug 2023</b>	11 Feb 2023	11 Aug 2021
Machine Age	yrs	Client Info	<b>10</b>	71546	0
Oil Age	yrs	Client Info	<b>0</b>	71546	0
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>1</b>	0	1
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >5	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >5	<b>&lt;1</b>	<1	0
Lead	ppm	ASTM D5185m >10	<b>1</b>	2	2
Copper	ppm	ASTM D5185m >50	<b>24</b>	23	26
Tin	ppm	ASTM D5185m >5	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 0	<b>0</b>	3	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	0
Magnesium	ppm	ASTM D5185m 0	<b>1</b>	11	0
Calcium	ppm	ASTM D5185m 75	<b>75</b>	77	72
Phosphorus	ppm	ASTM D5185m 275	<b>389</b>	359	348
Zinc	ppm	ASTM D5185m 350	<b>496</b>	479	460
Sulfur	ppm	ASTM D5185m 550	<b>1669</b>	1352	1083

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	1	<1
Sodium	ppm	ASTM D5185m	<b>1</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	<b>▲ 10591</b>	▲ 10774	▲ 49840
Particles >6µm	ASTM D7647	>640	<b>▲ 1210</b>	▲ 1347	▲ 4668
Particles >14µm	ASTM D7647	>80	<b>33</b>	66	68
Particles >21µm	ASTM D7647	>20	<b>10</b>	25	18
Particles >38µm	ASTM D7647	>4	<b>0</b>	2	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>▲ 21/17/12</b>	▲ 21/18/13	▲ 23/19/13


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.28</b>	0.32	0.342




# OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68.0	68.2	67.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

## GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : MW0049542 Received : 28 Aug 2023  
 Lab Number : 05936636 Diagnosed : 29 Aug 2023  
 Unique Number : 10621907 Diagnostician : Don Baldrige  
 Test Package : MAR 2 ( Additional Tests: PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

INGRAM BARGE

900 S 3RD ST  
 PADUCAH, KY  
 US 42003

Contact: DALE MORIE  
 dale.morie@ingrambarga.com

T: (270)415-4467  
 F: (615)695-3697