


PROBLEM SUMMARY


Area
RED HILLS WEST
 Machine Id
GOLDEN BEAR (S/N LE11193)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	NORMAL	ABNORMAL
Particles >6µm	ASTM D7647 >1300	▲ 1413	480	▲ 4977
Oil Cleanliness	ISO 4406 (c) >20/17/15	▲ 20/18/14	20/16/12	▲ 20/19/17

Customer Id: EOGMID
 Sample No.: TO60001212
 Lab Number: 05936650
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

13 Apr 2023 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



15 Nov 2022 Diag: Jonathan Hester

WATER



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



20 Jul 2022 Diag: Jonathan Hester

WATER




We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
RED HILLS WEST
Machine Id
GOLDEN BEAR (S/N LE11193)
Component
Compressor
Fluid
TULCO LUBSOIL LPG WS 150 (--- GAL)



DIAGNOSIS

Recommendation
No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO60001212	TO60000808	TO70000186
Sample Date	Client Info	10 Aug 2023	13 Apr 2023	15 Nov 2022
Machine Age	hrs	10205	8463	4918
Oil Age	hrs	1800	4198	0
Oil Changed	Client Info	Not Chngd	N/A	N/A
Sample Status		ATTENTION	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	1	2	1
Chromium	ppm	ASTM D5185m >10	0	1	<1
Nickel	ppm	ASTM D5185m	<1	<1	<1
Titanium	ppm	ASTM D5185m	0	<1	0
Silver	ppm	ASTM D5185m	0	1	0
Aluminum	ppm	ASTM D5185m >25	<1	0	2
Lead	ppm	ASTM D5185m >25	0	<1	1
Copper	ppm	ASTM D5185m >50	<1	<1	<1
Tin	ppm	ASTM D5185m >15	<1	<1	2
Vanadium	ppm	ASTM D5185m	0	1	<1
Cadmium	ppm	ASTM D5185m	0	1	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	0	<1	<1
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	<1	<1
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 0	1	<1	3
Calcium	ppm	ASTM D5185m 0	0	2	0
Phosphorus	ppm	ASTM D5185m 0	7	3	26
Zinc	ppm	ASTM D5185m 0	0	0	2
Sulfur	ppm	ASTM D5185m 0	295	45	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<1	2	<1
Sodium	ppm	ASTM D5185m	3	27	0
Potassium	ppm	ASTM D5185m >20	2	6	4
Water	%	ASTM D6304 >2.26	0.626	0.365	▲ 0.418
ppm Water	ppm	ASTM D6304 >22600	6265.3	3650	▲ 4180






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	5884	5493	9137
Particles >6µm	ASTM D7647 >1300	▲ 1413	480	▲ 4977
Particles >14µm	ASTM D7647 >320	89	25	▲ 847
Particles >21µm	ASTM D7647 >80	14	6	▲ 285
Particles >38µm	ASTM D7647 >20	1	1	▲ 44
Particles >71µm	ASTM D7647 >4	0	0	4
Oil Cleanliness	ISO 4406 (c) >20/17/15	▲ 20/18/14	20/16/12	▲ 20/19/17

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.18	0.16	0.06

OIL ANALYSIS REPORT









VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	151	130	144
Visc @ 100°C	cSt	ASTM D445	28	24.0	25.2
Viscosity Index (VI)	Scale	ASTM D2270	224	217	210

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO60001212 **Received** : 28 Aug 2023
Lab Number : 05936650 **Diagnosed** : 29 Aug 2023
Unique Number : 10621921 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

MIDLAND - EOG RESOURCES INC.
 5509 CHAMPIONS DRIVE
 MIDLAND, TX
 US 79706
 Contact: HERMAN GARZA
 herman_garza@eogresources.com
 T: (432)686-3600
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)