


PROBLEM SUMMARY

KAESER CSD 60 6570001 (S/N 1504)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS ABNORMAL NORMAL Sample Status ABNORMAL Particles >6µm ASTM D7647 >1300 28237 ▲ 37455 567 Particles >14µm ASTM D7647 >80 5801 ▲ 863 51 Particles >21µm ASTM D7647 >20 1741 73 13 Particles >38µm ASTM D7647 >4 **6**4 0 1 **Oil Cleanliness** ISO 4406 (c) >--/17/13 🔺 23/22/20 🔺 24/22/17 16/13


Customer Id: PARBROKCP Sample No.: KC109000 Lab Number: 05936680 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

21 Feb 2023 Diag: Don Baldridge



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

02 Feb 2022 Diag: Angela Borella



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

16 Mar 2021 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

view report



Report Id: PARBROKCP	WUSCAR	05936680	(Generated: 08/29/2023	16:41:49)	Rev: 1



OIL ANALYSIS REPORT

KAESER CSD 60 6570001 (S/N 1504)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM		method	limit/base	current	history1	history2
		Client Info	- mm/base	KC109000	KC105655	KC95920
Sample Number Sample Date		Client Info		21 Jul 2023	21 Feb 2023	02 Feb 2022
	hrs	Client Info		37802	34088	24915
Machine Age	hrs	Client Info		0	9173	3040
Oil Age Oil Changed	1115	Client Info		0 Not Changd		
Sample Status		Client Inio		ABNORMAL	Changed ABNORMAL	Changed NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	11	2	6
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	1	<1	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		8	11	7
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon		ASTM D5185m		1	2	<1
Sodium	ppm	ASTM D5185m	>23	<1	<1	0
Potassium	ppm	ASTM D5185m	>20	<1 0	0	0
Water	ppm %	ASTM D5185III ASTM D6304		0.009	0.005	0.004
ppm Water	% ppm	ASTM D6304 ASTM D6304		98.7	58.5	43.6
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	millbase	45570	82793	2796
Particles >6µm		ASTM D7647 ASTM D7647	<1300	A 28237	A 37455	567
Particles >14µm		ASTM D7647 ASTM D7647	>80	▲ 5801	▲ 863	567
Particles >21µm		ASTM D7647 ASTM D7647		5001 1741	▲ 73	13
				▲ 1741 ▲ 64	1	0
Particles >38µm		ASTM D7647	>4	3	0	
Particles >71µm Oil Cleanliness		ASTM D7647 ISO 4406 (c)	>3	3 <u> 3</u> <u> </u>	0 <u> </u>	0 16/13
		()				
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.39	0.43




OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.4	44.4	43.7
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color				a.		



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: TERRY CLEMENT - PARBROKCP