


# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**6338627 (S/N 1087)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCPA005905</b>	KCP40943	---
Sample Date	Client Info			<b>20 Aug 2023</b>	03 Apr 2022	---
Machine Age	hrs	Client Info		<b>26845</b>	17271	---
Oil Age	hrs	Client Info		<b>0</b>	3000	---
Oil Changed	Client Info			<b>N/A</b>	Changed	---
Sample Status				<b>NORMAL</b>	ATTENTION	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>&lt;1</b>	1	---
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	1	---
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	0	---
Silver	ppm	ASTM D5185m	>2	<b>0</b>	<1	---
Aluminum	ppm	ASTM D5185m	>10	<b>1</b>	1	---
Lead	ppm	ASTM D5185m	>10	<b>0</b>	<1	---
Copper	ppm	ASTM D5185m	>50	<b>3</b>	2	---
Tin	ppm	ASTM D5185m	>10	<b>0</b>	1	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>0</b>	<1	---
Barium	ppm	ASTM D5185m	90	<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	<1	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Magnesium	ppm	ASTM D5185m	100	<b>11</b>	49	---
Calcium	ppm	ASTM D5185m	0	<b>0</b>	<1	---
Phosphorus	ppm	ASTM D5185m	0	<b>3</b>	10	---
Zinc	ppm	ASTM D5185m	0	<b>11</b>	7	---
Sulfur	ppm	ASTM D5185m	23500	<b>23354</b>	17488	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>&lt;1</b>	6	---
Sodium	ppm	ASTM D5185m		<b>3</b>	10	---
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	2	---
Water	%	ASTM D6304	>0.05	<b>0.007</b>	0.019	---
ppm Water	ppm	ASTM D6304	>500	<b>70.0</b>	191.0	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>2984</b>	4419	---
Particles >6µm		ASTM D7647	>1300	<b>447</b>	▲ 1475	---
Particles >14µm		ASTM D7647	>80	<b>23</b>	▲ 148	---
Particles >21µm		ASTM D7647	>20	<b>7</b>	▲ 35	---
Particles >38µm		ASTM D7647	>4	<b>1</b>	2	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	<b>19/16/12</b>	▲ 18/14	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.47</b>	0.43	---


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.7	46.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA005905 **Received** : 28 Aug 2023  
**Lab Number** : 05936706 **Diagnosed** : 30 Aug 2023  
**Unique Number** : 10621977 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**ASTRA**  
 1900 SKYHAWK ST  
 ALAMEDA, CA  
 US 94501  
 Contact: D. RAWLINGS  
 drawlings@astra.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)