


## **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



# KAESER 6338613

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Dm2020 Mm2021 Jun2021 Aug2021 Jan2022 Jun2022 Feb2023 Mm2023 Aug2023						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC108288	KC101337	KC101611
Sample Date		Client Info		15 Aug 2023	22 May 2023	03 Feb 2023
Machine Age	hrs	Client Info		29143	28108	26120
Oil Age	hrs	Client Info		1200	6400	4400
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	1	5	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	68	29	39
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	87	54	69
Calcium	ppm	ASTM D5185m	2	2	1	2
Phosphorus	ppm	ASTM D5185m		1	0	34
Zinc	ppm	ASTM D5185m		0	5	4
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	10	6
Sodium	ppm	ASTM D5185m		19	23	31
Potassium	ppm	ASTM D5185m	>20	3	8	10
Water	%	ASTM D6304	>0.05	0.019	0.018	0.011
ppm Water	ppm	ASTM D6304	>500	199.3	181.6	116.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1173	844	491
Particles >6µm		ASTM D7647	>1300	371	256	122
Particles >14μm		ASTM D7647	>80	25	14	6
Particles >21μm		ASTM D7647	>20	6	2	1
Particles >38μm		ASTM D7647	>4	0	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/12	17/15/11	16/14/10
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34	0.32	0.35



## **OIL ANALYSIS REPORT**



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: Service Manager