




Machine Id  
**Press #7 Press #7**

Component  
**Hydraulic System**

Fluid  
**KLUBER KLUBEROIL 4 UH1-46 N (220 GAL)**



**DIAGNOSIS**

**Recommendation**

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

**Wear**

All component wear rates are normal.

**Contamination**

MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The amount and size of particulates present in the system are acceptable.

**Fluid Condition**

The AN level is acceptable for this fluid.

**SAMPLE INFORMATION**

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PTK0004615</b>	PTK0004623	PTK0004625
Sample Date	Client Info		<b>21 Aug 2023</b>	20 Jul 2023	19 Jun 2023
Machine Age	hrs	Client Info	<b>12047</b>	11549	10911
Oil Age	hrs	Client Info	<b>8351</b>	7853	7215
Oil Changed	Client Info		<b>Not Changed</b>	Not Changed	Not Changed
Sample Status			<b>SEVERE</b>	SEVERE	MARGINAL

**WEAR METALS**

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>8</b>	6	5
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	1
Lead	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Copper	ppm	ASTM D5185m >75	<b>&lt;1</b>	<1	0
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

**ADDITIVES**

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	4
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>7</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>25</b>	26	25
Zinc	ppm	ASTM D5185m	<b>20</b>	0	9
Sulfur	ppm	ASTM D5185m	<b>90</b>	67	120

**CONTAMINANTS**

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	<b>5</b>	4	3
Sodium	ppm	ASTM D5185m	<b>2</b>	1	<1
Potassium	ppm	ASTM D5185m >20	<b>2</b>	<1	0

**FLUID CLEANLINESS**


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>695</b>	329	393
Particles >6µm	ASTM D7647	>1300	<b>267</b>	102	108
Particles >14µm	ASTM D7647	>160	<b>27</b>	12	19
Particles >21µm	ASTM D7647	>40	<b>5</b>	3	5
Particles >38µm	ASTM D7647	>10	<b>0</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>17/15/12</b>	16/14/11	14/11

**FLUID DEGRADATION**


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.278</b>	0.258	0.225
MPC Varnish Potential	Scale	ASTM D7843 >15	<b>43</b>	52	22

# OIL ANALYSIS REPORT


### Varnish Potential




### Particle Trend




### Acid Number



### Viscosity @ 40°C



### Particle Trend




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	45.0	45.1	45.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


### Color








### Bottom



### MPC



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PTK0004615 **Received** : 29 Aug 2023  
**Lab Number** : 05937202 **Diagnosed** : 07 Sep 2023  
**Unique Number** : 10622473 **Diagnostician** : Doug Bogart  
**Test Package** : MOB 2 ( Additional Tests: MPC )

**NIAGARA BOTTLING**  
 11031 88TH AVE  
 PLEASANT PRAIRIE, WI  
 US 53158  
 Contact: TODD MONTGOMERY

To discuss this sample report, contact Customer Service at 1-800-237-1369.


\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (909)239-7599

F:

MPC (Varnish Test)



Sample Color & Clarity



*This page left intentionally blank*