

PROBLEM SUMMARY

Sample Rating Trend




Machine Id

KAESER ASD 25T 5107069 (S/N 1028)


Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL				
Water	%	ASTM D6304	>0.05	△ 0.120	△ 0.066	△ 0.370				
ppm Water	ppm	ASTM D6304	>500	1200	△ 660	△ 3700				

Customer Id: MIZBRA Sample No.: KC05937263 Lab Number: 05937263 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

11 Aug 2023 Diag: Doug Bogart

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. Free water present. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



WATER



03 May 2017 Diag: Don Baldridge

We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.



06 Feb 2017 Diag: Jonathan Hester

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



KAESER ASD 25T 5107069 (S/N 1028)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid.

	Feb 2017 May 2017 Aug 2023 Aug 2023						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		KC05937263	KC05937250	KC04226392	
Sample Date		Client Info		11 Aug 2023	11 Aug 2023	03 May 2017	
Machine Age	hrs	Client Info		0	13165	3401	
Oil Age	hrs	Client Info		0	0	857	
Oil Changed		Client Info		N/A	N/A	Not Changd	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	1	
Chromium	ppm	ASTM D5185m	>10	<1	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	<1	
Titanium	ppm	ASTM D5185m	>3	<1	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>10	6	<1	3	
Lead	ppm	ASTM D5185m	>10	<1	<1	0	
Copper	ppm	ASTM D5185m	>50	3	<1	1	
Tin	ppm	ASTM D5185m	>10	<1	0	0	
Antimony	ppm	ASTM D5185m				0	
Vanadium	ppm	ASTM D5185m		<1	<1	<1	
Cadmium	ppm	ASTM D5185m		<1	<1	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	2	
Barium	ppm	ASTM D5185m	90	0	0	31	
Molybdenum	ppm	ASTM D5185m		0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	<1	
Magnesium	ppm	ASTM D5185m	90	18	6	54	
Calcium	ppm	ASTM D5185m		0	0	1	
Phosphorus	ppm	ASTM D5185m	_	37	336	55	
Zinc	ppm	ASTM D5185m		25	19	26	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1	
Sodium	ppm	ASTM D5185m	725	12	1	11	
Potassium		ASTM D5185m	>20	11	2	5	
Water	ppm %	ASTM D5165111	>0.05	△ 0.120	△ 0.066	△ 0.370	
ppm Water	ppm	ASTM D6304		▲ 1200	▲ 660	▲ 3700	
FLUID CLEANLIN		method	limit/base	current	history1	history2	
Particles >4µm	00	ASTM D7647	mmbase	6867	505	8546	
Particles >6µm		ASTM D7647	>1300	842	275	△ 2678	
Particles >14µm		ASTM D7647	>80	48	47	△ 218	
Particles >14µm		ASTM D7647		14	16	△ 65	
Particles >38µm		ASTM D7647	>4	14	2	▲ 10	
Particles >71µm		ASTM D7647		0	0	▲ 8 ▲ 40/4F	
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/17/13	16/15/13	▲ 19/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	

0.22

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.092

0.358



OIL ANALYSIS REPORT



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact:

T: F: