PROBLEM SUMMARY

Sample Rating Trend



ISO

Machine Id
KF-CV 1-PUMP 1 (S/N U161300130)
Component
Pump
Fluid
USPI VAC 100 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	ABNORMAL
Particles >4µm		ASTM D7647	>5000	▲ **10549**	---	▲ 6199
Particles >6µm		ASTM D7647	>1300	▲ **3320**	---	▲ 2820
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **21/19/14**	---	▲ 20/19/16

Customer Id: JBSTOL
Sample No.: USPM27269
Lab Number: 05937270
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

19 Mar 2023 Diag: Doug Bogart

WATER

We advise that you follow the water drain-off procedure for this component and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles and water present in this sample.All component wear rates are normal. Appearance is unacceptable. There is a high concentration of water present in the oil. Excessive free water present. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

view report

20 Dec 2022 Diag: Doug Bogart

ISO

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

05 Oct 2022 Diag: Doug Bogart

WATER

Resample at the next service interval to monitor.All component wear rates are normal. Appearance is hazy. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
KF-CV 1-PUMP 1 (S/N U161300130)
Component
Pump
Fluid
USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USPM27269**	USPM27541	USPM24439
Sample Date		Client Info		**28 Aug 2023**	19 Mar 2023	20 Dec 2022
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	SEVERE	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	**23**	8	0
Chromium	ppm	ASTM D5185m	>5	**<1**	0	0
Nickel	ppm	ASTM D5185m	>5	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**<1**	0	0
Silver	ppm	ASTM D5185m	>3	**0**	0	0
Aluminum	ppm	ASTM D5185m	>7	**<1**	1	<1
Lead	ppm	ASTM D5185m	>12	**<1**	0	0
Copper	ppm	ASTM D5185m	>30	**<1**	0	0
Tin	ppm	ASTM D5185m	>9	**<1**	<1	0
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**<1**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	**2**	2	0
Barium	ppm	ASTM D5185m	0	**0**	0	0
Molybdenum	ppm	ASTM D5185m	0	**0**	0	0
Manganese	ppm	ASTM D5185m		**<1**	<1	0
Magnesium	ppm	ASTM D5185m	0	**6**	2	0
Calcium	ppm	ASTM D5185m	0	**0**	0	0
Phosphorus	ppm	ASTM D5185m	1800	**904**	1134	1207
Zinc	ppm	ASTM D5185m	0	**20**	0	0
Sulfur	ppm	ASTM D5185m	0	**26**	0	20

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	**4**	6	<1
Sodium	ppm	ASTM D5185m		**5**	7	<1
Potassium	ppm	ASTM D5185m	>20	**3**	2	0
Water	%	ASTM D6304		**0.096**	1.44	0.072
ppm Water	ppm	ASTM D6304	>.1	**966.9**	14400	723.9

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**10549**	---	6199
Particles >6µm		ASTM D7647	>1300	**3320**	---	2820
Particles >14µm		ASTM D7647	>160	**148**	---	497
Particles >21µm		ASTM D7647	>40	**24**	---	154
Particles >38µm		ASTM D7647	>10	**3**	---	5
Particles >71µm		ASTM D7647	>3	**1**	---	1
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**21/19/14**	---	20/19/16

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	**1.59**	0.17	0.17

OIL ANALYSIS REPORT

Particle Trend



Water



Acid Number



Water



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	▲ MODER	VLITE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	▲ MILKY	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual		**NEG**	⬢ 0.2%	NEG
Free Water	scalar	*Visual		**NEG**	⬢ 2.0	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	**90.6**	90.0	101

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM27269
Lab Number : 05937270
Unique Number : 10622541
Test Package : IND 2

Received : 29 Aug 2023
Diagnosed : 30 Aug 2023
Diagnostician : Doug Bogart

Certificate L2367

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

JBS - TOLLESON

TOLLESON, AZ
US 85353
Contact:

T:
F: