




PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY




Machine Id
#4 NH3 TYSDCP 4 SUL (S/N 007-00001323)
 Component
Refrigeration Compressor
 Fluid
USPI 1009-68 SC (--- GAL)




COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Particle Trend



RECOMMENDATION

The oil is near the end of its useful service life and we recommend schedule an oil change. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	MARGINAL	NORMAL
Particles >6µm	ASTM D7647	>2500	▲ 4708	2367	1565	
Oil Cleanliness	ISO 4406 (c)	>--/18/15	▲ 21/19/15	20/18/15	19/18/14	
Visc @ 40°C	cSt	ASTM D445	67	▲ 83.2	▲ 80.2	78.6

Customer Id: IBPDAK01
 Sample No.: USP0000408
 Lab Number: 05937287
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Service/change Fluid	---	---	?	The oil is near the end of it's useful service life, recommend schedule an oil change.

HISTORICAL DIAGNOSIS

21 May 2023 Diag: Doug Bogart

VISCOSITY



The oil is near the end of it's useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid.

view report



23 Apr 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. An increase in the viscosity is noted. Confirmed. The AN level is acceptable for this fluid.

view report



05 Dec 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. REPLACED OIL 11/10/22 THIS IS A 500 HR SAMPLE All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Machine Id
#4 NH3 TYSDCP 4 SUL (S/N 007-00001323)
 Component
Refrigeration Compressor
 Fluid
USPI 1009-68 SC (--- GAL)

DIAGNOSIS

Recommendation

The oil is near the end of its useful service life and we recommend schedule an oil change. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP0000408	USP243670	USP248063
Sample Date	Client Info		28 Aug 2023	21 May 2023	23 Apr 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	MARGINAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<1	1	3
Chromium	ppm	ASTM D5185m >2	<1	0	0
Nickel	ppm	ASTM D5185m	0	<1	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >3	0	0	0
Lead	ppm	ASTM D5185m >2	<1	0	0
Copper	ppm	ASTM D5185m >8	<1	0	0
Tin	ppm	ASTM D5185m >4	0	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	0	<1	0
Calcium	ppm	ASTM D5185m	0	0	0
Phosphorus	ppm	ASTM D5185m	1	<1	0
Zinc	ppm	ASTM D5185m	2	0	0
Sulfur	ppm	ASTM D5185m 50	0	8	0

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	2	2	<1
Sodium	ppm	ASTM D5185m	<1	0	<1
Potassium	ppm	ASTM D5185m >20	2	<1	1
Water	%	ASTM D6304 >0.01	0.003	0.004	0.001
ppm Water	ppm	ASTM D6304 >100	29.9	41.4	14.0

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		16226	7167	4530
Particles >6µm	ASTM D7647	>2500	▲ 4708	2367	1565
Particles >14µm	ASTM D7647	>320	281	240	114
Particles >21µm	ASTM D7647	>80	43	61	29
Particles >38µm	ASTM D7647	>20	2	15	0
Particles >71µm	ASTM D7647	>4	0	4	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	▲ 21/19/15	20/18/15	19/18/14

FLUID DEGRADATION


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.005	0.043	0.015	0.013

OIL ANALYSIS REPORT


▲ Particle Trend




Water




▲ Particle Trend



Acid Number




Water





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 67	▲ 83.2	▲ 80.2	78.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0000408 **Received** : 29 Aug 2023
Lab Number : 05937287 **Diagnosed** : 30 Aug 2023
Unique Number : 10622558 **Diagnostician** : Doug Bogart
Test Package : IND 2

TYSON-DAKOTA CITY-UP
 P.O. BOX 515
 DAKOTA CITY, NE
 US 68731
 Contact: RICHARD KOCH

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (605)235-2396
 F: (605)235-2960