

OIL ANALYSIS REPORT

Sample Rating Trend



FES TYSDCP 6 FES (S/N XA0236)

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

g2012 Oct2013 Jan2015 May2016 Nev/2017 Jul2019 Dec2020 Jun2022						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0000404	USP243672	USP246844
Sample Date		Client Info		28 Aug 2023	21 May 2023	06 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	2	0
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	<1	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	<1	0	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		<1	1	0
Zinc	ppm	ASTM D5185m		2	0	0
Sulfur	ppm	ASTM D5185m	50	<1	23	21
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	2	1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>0.01	0.005	0.004	0.003
ppm Water	ppm	ASTM D6304	>100	50.9	46.6	28.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2178	637	3812
Particles >6µm		ASTM D7647	>2500	548	386	838
Particles >14μm		ASTM D7647	>320	29	42	17
Particles >21μm		ASTM D7647	>80	9	10	3
Particles >38μm		ASTM D7647	>20	0	5	0
Particles >71μm		ASTM D7647	>4	0	3	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	18/16/12	16/16/13	19/17/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A : I N I (AND	1/011/	4 OTM 1 DOT 4	0.005	0.015	0.045	0.011

Acid Number (AN)

0.015

0.015

mg KOH/g ASTM D974 0.005

0.014



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number

Unique Number Test Package

: USP0000404 : 05937291 : 10622562 : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 29 Aug 2023 : 30 Aug 2023 Diagnosed

: Doug Bogart Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

P.O. BOX 515 DAKOTA CITY, NE US 68731

Contact: RICHARD KOCH

Contact/Location: RICHARD KOCH - IBPDAK01

T: (605)235-2396 F: (605)235-2960