


PROBLEM SUMMARY



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|--------|------------|-------|----------------|-------------|-------------|--|--|
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL | | |
| Water | % | ASTM D6304 | >0.2 | A 0.706 | 0.039 | 0.093 | | |
| ppm Water | ppm | ASTM D6304 | >2000 | <u> </u> | 390 | 930 | | |
| White Metal | scalar | *Visual | NONE | 🔺 MODER | 🔺 MODER | MODER | | |
| Emulsified Water | scalar | *Visual | >0.2 | A 0.2% | 0.2% | ▲ 0.2% | | |
| Free Water | scalar | *Visual | | <u> </u> | 1 .0 | 1 .0 | | |


Customer Id: KIMMOBUTL Sample No.: RP0023531 Lab Number: 05937839 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



| RECOMMENDED A | CTIONS | | | |
|--------------------|--------|------|---------|---|
| Action | Status | Date | Done By | Description |
| Change Filter | | | ? | We recommend you service the filters on this component if applicable. |
| Water Drain-off | | | ? | We advise that you follow the water drain-off procedure for this component. |
| Resample | | | ? | We recommend an early resample to monitor this condition. |
| Alert | | | ? | We were unable to perform a particle count due to metal particles present in this sample. |
| Check Water Access | | | ? | We advise that you check for the source of water entry. |

HISTORICAL DIAGNOSIS

04 Jun 2023 Diag: Don Baldridge

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. Free water present. The AN level is acceptable for this fluid.



view report

UF

02 Mar 2023 Diag: Angela Borella

We advise that you check for the source of water entry. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

25 Jan 2023 Diag: Don Baldridge

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT



SHELL OMALA 680 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

🔺 Wear

Moderate concentration of visible metal present. All component wear rates are normal.

Contamination

Free water present. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.




| SAMPLE INFORM | ATION | method | limit/base | current | history1 | history2 |
|--|-------|--|---|----------------|-------------|-------------|
| Sample Number | | Client Info | | RP0023531 | RP0023560 | RP0006310 |
| Sample Date | | Client Info | | 28 Aug 2023 | 04 Jun 2023 | 02 Mar 2023 |
| Machine Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| PQ | | ASTM D8184 | | 43 | 88 | 59 |
| Iron | ppm | ASTM D5185m | >200 | 30 | 61 | 29 |
| Chromium | ppm | ASTM D5185m | >15 | <1 | <1 | 0 |
| Nickel | ppm | ASTM D5185m | >15 | 0 | <1 | 0 |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >25 | 3 | 0 | <1 |
| Lead | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >200 | 0 | <1 | <1 |
| Tin | ppm | ASTM D5185m | | 0 | <1 | <1 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| ADDITIVES | pp | | 11 | - | | |
| | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | | <1 | 0 | 4 |
| Calcium | ppm | ASTM D5185m | | 17 | 6 | 8 |
| Phosphorus | ppm | ASTM D5185m | 512 | 103 | 239 | 123 |
| Zinc | ppm | ASTM D5185m | 3.8 | 6 | 0 | 8 |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >50 | 13 | 14 | 10 |
| Sodium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 2 | 0 |
| Water | % | ASTM D6304 | >0.2 | A 0.706 | 0.039 | 0.093 |
| ppm Water | ppm | ASTM D6304 | >2000 | A 7060 | 390 | 930 |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| | | | | Current | | |
| Particles >4µm | | ASTM D7647 | >20000 | | | |
| Particles >4µm Particles >6µm | | ASTM D7647 ASTM D7647 | | | | |
| • | | | >20000 | | | |
| Particles >6µm | | ASTM D7647 | >20000 >5000 | | | |
| Particles >6μm Particles >14μm | | ASTM D7647 ASTM D7647 | >20000 >5000 >640 | | | |
| Particles >6μm Particles >14μm Particles >21μm | | ASTM D7647 ASTM D7647 ASTM D7647 | >20000 >5000 >640 >160 >40 | | | |
| Particles >6μm Particles >14μm Particles >21μm Particles >38μm | | ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 | >20000 >5000 >640 >160 >40 | | | |
| Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm | | ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 | >20000 >5000 >640 >160 >40 >10 | | | |

Contact/Location: RALPH EVANS - KIMMOBUTL



OIL ANALYSIS REPORT



Aar2/23

Viscosity @ 40°C


800


75 70 un4/73


VISUAL method limit/base history1 history2 current MODER White Metal *Visual NONE MODER scalar MODER Yellow Metal NONE NONE NONE scalar *Visual NONE Precipitate scalar *Visual NONE NONE NONE NONE Silt scalar *Visual NONE NONE NONE NONE NONE Debris *Visual NONE NONE MODER scalar NONE Sand/Dirt scalar *Visual NONE NONE NONE NORML Appearance NORML NORML NORML scalar *Visua NORML NORML Odor scalar *Visual NORML NORML *Visual **Emulsified Water** scalar >0.2 0.2% 0.2% ▲ 0.2% Free Water scalar *Visual 1.0 1.0 **1.0 FLUID PROPERTIES** method limit/base curren history history Visc @ 40°C cSt ASTM D445 680 658 664 673 SAMPLE IMAGES limit/base history2 method current history1 Color

Bottom









Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Kimberly-Clark - Mobile - UTL Sample No. 200 BAYBRIDGE RD : RP0023531 Received : 29 Aug 2023 Lab Number : 05937839 Diagnosed : 14 Sep 2023 MOBILE, AL US 36610 Unique Number : 10628451 Diagnostician : Doug Bogart Test Package : IND 2 (Additional Tests: PQ, PrtCount) Contact: RALPH EVANS Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. ralph.h.evans@kcc.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (251)330-2250 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (251)452-6335

Report Id: KIMMOBUTL [WUSCAR] 05937839 (Generated: 09/14/2023 21:15:14) Rev: 1

Contact/Location: RALPH EVANS - KIMMOBUTL



