

PROBLEM SUMMARY

{UNASSIGNED}

MCQUAY Hills & Dale Hospital (circuit # 2) (S/N STNU060600018) Component Chiller

Fluic

NOT GIVEN (4 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	
Particles >4µm	ASTM D7647 >1000	0 🔺 209138	
Particles >6µm	ASTM D7647 >2500	<mark>▲ 82543</mark>	
Particles >14µm	ASTM D7647 >320	<u> </u>	
Particles >21µm	ASTM D7647 >80	<u> </u>	
Oil Cleanliness	ISO 4406 (c) >20/18	3/15 🔺 25/24/18	


Customer Id: THEAUB Sample No.: WC0618921 Lab Number: 05937904 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		
Information Required			?	Please specify the brand, type, and viscosity of the oil on your next sample.		

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Area **{UNASSIGNED}** Machine Id MCQUAY Hills & Dale Hospital (circuit # 2) (S/N STNU060600018) Component

Chiller Fluid

NOT GIVEN (4 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

				Aug2023		
SAMPLE INFORM		method	limit/base	current	history1	history2
Sample Number		Client Info		WC0618921		
Sample Date		Client Info		10 Aug 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		21481		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	7		
Chromium	ppm	ASTM D5185m	>2	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>50	3		
Lead	ppm	ASTM D5185m	>2	0		
Copper	ppm	ASTM D5185m		<1		
Tin	ppm	ASTM D5185m	>4	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES	ppm		limit/base	-		
		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		1321		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		32		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	23		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304	>0.01	0.007		
ppm Water	ppm	ASTM D6304	>100	77.2		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u> </u>		
Particles >6µm		ASTM D7647	>2500	<u> </u>		
Particles >14µm		ASTM D7647	>320	🔺 1694		
Particles >21µm		ASTM D7647	>80	<u> </u>		
Particles >38µm		ASTM D7647	>20	1		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	A 25/24/18		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.014		

Sample Rating Trend ISO



OIL ANALYSIS REPORT



Submitted By: SHELLY MANN

Page 4 of 4

:1999 Cle