




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
Extrusion
 Machine Id
Press 3 Press Hydraulic Unit (S/N 84356)
 Component
Hydraulic System
 Fluid
AW HYDRAULIC OIL ISO 46 (3962 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			RP0024726	RP0024731	RP0029961
Sample Date	Client Info			25 Aug 2023	30 Jun 2023	23 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ATTENTION

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	1	<1	<1
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	<1	<1	<1
Lead	ppm	ASTM D5185m	>20	2	<1	0
Copper	ppm	ASTM D5185m	>20	11	7	8
Tin	ppm	ASTM D5185m	>20	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	3	0	0
Barium	ppm	ASTM D5185m	5	2	<1	0
Molybdenum	ppm	ASTM D5185m	5	8	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	25	12	2	0
Calcium	ppm	ASTM D5185m	200	79	36	9
Phosphorus	ppm	ASTM D5185m	300	342	345	355
Zinc	ppm	ASTM D5185m	370	454	407	390

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	<1	3
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	2	1	0
Water	%	ASTM D6304	>0.05	0.001	0.003	0.004
ppm Water	ppm	ASTM D6304	>500	4.2	39.5	46.9

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	985	1263	▲ 6437
Particles >6µm		ASTM D7647	>1300	134	231	▲ 1934
Particles >14µm		ASTM D7647	>160	19	27	▲ 256
Particles >21µm		ASTM D7647	>40	8	11	▲ 93
Particles >38µm		ASTM D7647	>10	0	1	6
Particles >71µm		ASTM D7647	>3	0	0	1
Oil Cleanliness		ISO 4406 (c)	>19/17/14	17/14/11	17/15/12	▲ 20/18/15

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.57	0.41	0.36	0.54

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.7	45.5	45.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0024726 **Received** : 30 Aug 2023
Lab Number : 05938263 **Diagnosed** : 31 Aug 2023
Unique Number : 10628875 **Diagnostician** : Wes Davis
Test Package : IND 2

WESTERN EXTRUSIONS CORPORATION
 1735 SANDY LAKE RD
 CARROLLTON, TX
 US 75006
 Contact: WESTERN EXTRUSIONS
 SHAYLEY@WESTERNEXTRUSIONS.COM
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)