


PROBLEM SUMMARY

KAESER SX 7.5T 6225671 (S/N 1003)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | ABNORMAL ABNORM | 1AL |
|-----------------|------------------|-------------------------|-----|
| Particles >6µm | ASTM D7647 >130 | 00 🔺 5408 🔺 24249 | |
| Particles >14µm | ASTM D7647 >80 | ▲ 315 ▲ 1227 | |
| Particles >21µm | ASTM D7647 >20 | ▲ 48 ▲ 94 | |
| Oil Cleanliness | ISO 4406 (c) >/1 | 7/13 🔺 21/20/15 🔺 22/17 | |


Customer Id: AQUFRECO Sample No.: KCPA003590 Lab Number: 05938312 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



| RECOMMENDED ACTIONS | | | | | | |
|---------------------|--------|------|---------|---|--|--|
| Action | Status | Date | Done By | Description | | |
| Change Fluid | | | ? | Oil and filter change at the time of sampling has been noted. | | |
| Change Filter | | | ? | Oil and filter change at the time of sampling has been noted. | | |

HISTORICAL DIAGNOSIS



02 Feb 2019 Diag: Jonathan Hester

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

KAESER SX 7.5T 6225671 (S/N 1003)

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



| SAMPLE INFORI | MATION | method | limit/base | current | history1 | history2 |
|-----------------|--------|--------------|------------|-------------------|----------------|----------|
| Sample Number | | Client Info | | KCPA003590 | KCP11514 | |
| Sample Date | | Client Info | | 21 Aug 2023 | 02 Feb 2019 | |
| Machine Age | hrs | Client Info | | 8242 | 528 | |
| Oil Age | hrs | Client Info | | 0 | 247 | |
| Oil Changed | | Client Info | | Changed | Changed | |
| Sample Status | | | | ABNORMAL | ABNORMAL | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | 2 | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | <1 | |
| Lead | ppm | ASTM D5185m | >10 | 0 | <1 | |
| Copper | ppm | ASTM D5185m | | 20 | 2 | |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | |
| Antimony | ppm | ASTM D5185m | | | 0 | |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| | ppm | | 11 | - | - | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 0 | 0 | <1 | |
| Barium | ppm | ASTM D5185m | 90 | <1 | 10 | |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | |
| Magnesium | ppm | ASTM D5185m | 100 | 0 | 73 | |
| Calcium | ppm | ASTM D5185m | 0 | 0 | 2 | |
| Phosphorus | ppm | ASTM D5185m | 0 | <1 | 3 | |
| Zinc | ppm | ASTM D5185m | 0 | 0 | 8 | |
| Sulfur | ppm | ASTM D5185m | 23500 | 19693 | 23134 | |
| CONTAMINANTS | S | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | <1 | <1 | |
| Sodium | ppm | ASTM D5185m | | 0 | 15 | |
| Potassium | ppm | ASTM D5185m | >20 | <1 | 2 | |
| Water | % | ASTM D6304 | >0.05 | 0.008 | 0.013 | |
| ppm Water | ppm | ASTM D6304 | >500 | 89.5 | 130 | |
| FLUID CLEANLIN | NESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | | 12407 | 46773 | |
| Particles >6µm | | ASTM D7647 | >1300 | <u> </u> | A 24249 | |
| Particles >14µm | | ASTM D7647 | >80 | A 315 | <u> </u> | |
| Particles >21µm | | ASTM D7647 | >20 | <u> </u> | 9 4 | |
| Particles >38µm | | ASTM D7647 | >4 | 1 | 3 | |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 0 | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | A 21/20/15 | 2 2/17 | |
| FLUID DEGRAD | ATION | method | limit/base | current | history1 | history2 |
| | KOUK | | 1.0 | | | |


Acid Number (AN) m Report Id: AQUFRECO [WUSCAR] 05938312 (Generated: 08/31/2023 09:21:49) Rev: 1

mg KOH/g ASTM D8045 1.0


0.35 0.390 ----Contact/Location: Service Manager - AQUFRECO




OIL ANALYSIS REPORT









To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory

Sample No.

Lab Number

Contact/Location: Service Manager - AQUFRECO

T: F: