



FUEL REPORT

Sample Rating Trend

WATER



Machine Id
PORTS GAS TANK

Component
Gasoline
Fluid
NOT GIVEN (--- GAL)



DIAGNOSIS

▲ Recommendation

This is a baseline read-out on the submitted sample.

Wear

{not applicable}

▲ Contamination

There is a light concentration of water present in the gasoline. Anthrone test for sugar contamination is negative.

Fluid Condition

{not applicable}

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC05938488	---	---
Sample Date	Client Info		29 Aug 2023	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed		Client Info	N/A	---	---
Sample Status			MARGINAL	---	---



SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur (UVF)	ppm	ASTM D5453	6	---	---

CONTAMINANTS


	method	limit/base	current	history1	history2
Water	%	ASTM D6304	<0.05	▲ 0.144	---
ppm Water	ppm	ASTM D6304	<500	▲ 1449.6	---
% Gasoline	%	*In-House	<0.50	70.0	---
% Biodiesel	%	*In-House	<20.0	0.0	---

SAMPLE IMAGES



	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



FUEL REPORT



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC05938488 **Received** : 30 Aug 2023
Lab Number : **05938488** **Diagnosed** : 11 Sep 2023
Unique Number : 10629100 **Diagnostician** : Doug Bogart
Test Package : TEST (Additional Tests: Color-ASTM, GC-PercFuel, ICP, KF, KV40, PrtCount, Sugar, XRF)

GAINES OIL COMPANY
 2346 S MAIN ST
 GOLDSTON, NC
 US 27252
 Contact: CHIP POOLE
 chip@gainesoil.com
 T: (919)898-2231
 F: (919)898-2981

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)