




PROBLEM SUMMARY

Sample Rating Trend




WATER




Area
Element 13
 Machine Id
EL-SP-SHRD-0001-MILL-LUBE-SYST EL-SP-SHRD-0001-MILL-LUBE-SYST
 Component
Journal Bearing
 Fluid
QUAKER CHEMICAL QUINTOLUBRIC 888-68 (50 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water (KF)



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>2	▲ 0.109	---	---
ppm Water	ppm	ASTM D6304		▲ 1090	---	---
Particles >4µm		ASTM D7647	>10000	▲ 42628	---	▲ 110778
Oil Cleanliness		ISO 4406 (c)	>20/18/14	▲ 23/16/12	---	▲ 24/22/19
Emulsified Water	scalar	*Visual	>2	▲ 0.2%	NEG	NEG

Customer Id: CONMUSAL
 Sample No.: KFS0003888
 Lab Number: 05938830
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

18 May 2023 Diag: Don Baldrige

VISUAL METAL



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. No other contaminants were detected in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



29 Sep 2022 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



01 Sep 2022 Diag: Angela Borella

WEAR



We advise that you inspect for the source(s) of wear. Resample at the next service interval to monitor. The tin level is abnormal. Bearing wear is indicated. All other component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
Element 13
 Machine Id
EL-SP-SHRD-0001-MILL-LUBE-SYST EL-SP-SHRD-0001-MILL-LUBE-SYST
 Component
Journal Bearing
 Fluid
QUAKER CHEMICAL QUINTOLUBRIC 888-68 (50 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 6 microns in size) present in the oil. There is a trace of moisture present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0003888	KFS0003753	KFS0001848
Sample Date	Client Info	17 Aug 2023	18 May 2023	29 Sep 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >60	41	22	2
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >4	2	2	<1
Lead	ppm	ASTM D5185m >250	0	0	<1
Copper	ppm	ASTM D5185m >125	<1	<1	<1
Tin	ppm	ASTM D5185m >80	285	294	300
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m 0	<1	<1	0
Magnesium	ppm	ASTM D5185m 0	<1	0	0
Calcium	ppm	ASTM D5185m 10	5	3	0
Phosphorus	ppm	ASTM D5185m 200	101	118	114
Zinc	ppm	ASTM D5185m 125	0	0	0
Sulfur	ppm	ASTM D5185m 1000	612	634	715

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	4	4	2
Sodium	ppm	ASTM D5185m	4	3	2
Potassium	ppm	ASTM D5185m >20	3	<1	0
Water	%	ASTM D6304 >2	▲ 0.109	---	---
ppm Water	ppm	ASTM D6304	▲ 1090	---	---


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 42628	---	▲ 110778
Particles >6µm	ASTM D7647 >2500	575	---	▲ 33205
Particles >14µm	ASTM D7647 >160	23	---	▲ 3490
Particles >21µm	ASTM D7647 >40	6	---	▲ 1073
Particles >38µm	ASTM D7647 >10	1	---	▲ 39
Particles >71µm	ASTM D7647 >3	0	---	3
Oil Cleanliness	ISO 4406 (c) >20/18/14	▲ 23/16/12	---	▲ 24/22/19


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.5	1.67	1.70	1.64


▲ Particle Trend




▲ Water (KF)




▲ Water (KF)



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	▲ MODER	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	65.5	65.4

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0003888 **Received** : 30 Aug 2023
Lab Number : 05938830 **Diagnosed** : 21 Sep 2023
Unique Number : 10629442 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONSTELLIUM
 4805 SECOND STREET
 MUSCLE SHOALS, AL
 US 35661
 Contact: Joel Even
 joel.even@constellium.com
 T: (256)740-7490
 F: