




# PROBLEM SUMMARY

Sample Rating Trend




ISO



Area  
**Element 13**  
 Machine Id  
**EL-SP-SHRD-0002-MILL-LUBE-SYST EL-SP-SHRD-0002-MILL-LUBE-SYST**  
 Component  
**Journal Bearing**  
 Fluid  
**QUAKER CHEMICAL QUINTOLUBRIC 888-68 (50 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ 34477	▲ 80628	---
Particles >6µm	ASTM D7647	>2500	▲ 3096	▲ 8130	---
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 22/19/14	▲ 24/20/15	---

Customer Id: CONMUSAL  
 Sample No.: KFS0003890  
 Lab Number: 05938831  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 29 Sep 2022 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 01 Sep 2022 Diag: Angela Borella

VISUAL METAL



We advise that you inspect for the source(s) of wear. Resample at the next service interval to monitor. The tin level is abnormal. Moderate concentration of visible metal present. Bearing wear is indicated. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



### 27 Jan 2022 Diag: Don Baldrige

VISUAL METAL



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. No other contaminants were detected in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

## Element 13

Machine Id

### EL-SP-SHRD-0002-MILL-LUBE-SYST EL-SP-SHRD-0002-MILL-LUBE-SYST

Component

### Journal Bearing

Fluid

### QUAKER CHEMICAL QUINTOLUBRIC 888-68 (50 GAL)

#### DIAGNOSIS

##### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

##### Wear

All component wear rates are normal.

##### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

##### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KFS0003890</b>	KFS0001847	KFS0001932
Sample Date	Client Info		<b>18 May 2023</b>	29 Sep 2022	01 Sep 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

#### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >60	<b>2</b>	6	10
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >4	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185m >250	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >125	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m >80	<b>306</b>	306	▲ 301
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

#### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	2	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Calcium	ppm	ASTM D5185m 10	<b>4</b>	0	<1
Phosphorus	ppm	ASTM D5185m 200	<b>107</b>	118	116
Zinc	ppm	ASTM D5185m 125	<b>0</b>	1	6
Sulfur	ppm	ASTM D5185m 1000	<b>633</b>	811	641

#### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>1</b>	2	5
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	2	2
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	0


#### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ <b>34477</b>	▲ 80628	---
Particles >6µm	ASTM D7647	>2500	▲ <b>3096</b>	▲ 8130	---
Particles >14µm	ASTM D7647	>160	<b>128</b>	▲ 316	---
Particles >21µm	ASTM D7647	>40	<b>37</b>	▲ 91	---
Particles >38µm	ASTM D7647	>10	<b>1</b>	5	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ <b>22/19/14</b>	▲ 24/20/15	---


#### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.5	<b>1.57</b>	1.84	2.12


### ▲ Particle Trend




### ▲ Particle Trend



### Acid Number



### Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT ▲ MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	65.4	65.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KFS0003890 **Received** : 30 Aug 2023  
**Lab Number** : 05938831 **Diagnosed** : 31 Aug 2023  
**Unique Number** : 10629443 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**CONSTELLIUM**  
 4805 SECOND STREET  
 MUSCLE SHOALS, AL  
 US 35661

Contact: Joel Even  
 joel.even@constellium.com

T: (256)740-7490

F: