




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**[DR1582209]**  
 Machine Id  
**A320-1 SIMULATOR**  
 Component  
**Hydraulic System**  
 Fluid  
**SHELL TELLUS S3 M 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.  
 NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0803922</b>	WC0784100	WC0680005
Sample Date	Client Info	<b>26 Aug 2023</b>	23 Mar 2023	05 Sep 2022
Machine Age	mls	Client Info	<b>0</b>	0
Oil Age	mls	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>0</b>	0
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0
Silver	ppm	ASTM D5185m	<b>0</b>	0
Aluminum	ppm	ASTM D5185m >20	<b>&lt;1</b>	0
Lead	ppm	ASTM D5185m >20	<b>0</b>	1
Copper	ppm	ASTM D5185m >20	<b>0</b>	0
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0
Barium	ppm	ASTM D5185m	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	<1
Calcium	ppm	ASTM D5185m 55	<b>39</b>	41
Phosphorus	ppm	ASTM D5185m 60	<b>48</b>	48
Zinc	ppm	ASTM D5185m 0	<b>4</b>	11
Sulfur	ppm	ASTM D5185m 180	<b>194</b>	221

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>0</b>	0
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>1078</b>	1009
Particles >6µm	ASTM D7647	>1300	<b>337</b>	222
Particles >14µm	ASTM D7647	>160	<b>40</b>	13
Particles >21µm	ASTM D7647	>40	<b>16</b>	5
Particles >38µm	ASTM D7647	>10	<b>1</b>	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>17/16/12</b>	17/15/11


## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.2	<b>0.16</b>	0.18




# OIL ANALYSIS REPORT


**Particle Trend**




**Acid Number**



**Viscosity @ 40°C**



**Particle Trend**



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.3	43.8	44.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------






**Color**

**Bottom**

**MPC**

no image      no image      no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0803922      **Received** : 30 Aug 2023  
**Lab Number** : 05938835      **Diagnosed** : 31 Aug 2023  
**Unique Number** : 10629447      **Diagnostician** : Wes Davis  
**Test Package** : IND 2

**DENTK UNITED AIRLINES**  
 7401 MARTIN LUTHER KING BLVD.  
 DENVER, CO  
 US 80207  
 Contact: MARKUS MANGRA  
 markus.mangra@united.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: