




PROBLEM SUMMARY

Sample Rating Trend


ISO



Area
CTF
 Machine Id
Dyno Side B
 Component
Pump Bearing Lube
 Fluid
ESSO NUTO H ISO 68 (200 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. (Customer Sample Comment: Fluid and Filters changed in August 2022
 Filters changed again in August 2023)

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>640	▲ 746	198	97
Particles >6µm	ASTM D7647	>160	▲ 243	57	31
Oil Cleanliness	ISO 4406 (c)	>16/14/11	▲ 17/15/10	15/13/10	14/12/9

Customer Id: MICGRE
 Sample No.: WC0810916
 Lab Number: 05938897
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

15 Aug 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



04 Dec 2020 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
CTF
 Machine Id
Dyno Side B
 Component
Pump Bearing Lube
 Fluid
ESSO NUTO H ISO 68 (200 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. (Customer Sample Comment: Fluid and Filters changed in August 2022
 Filters changed again in August 2023)

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0810916	WC0500753	WC0500745
Sample Date	Client Info		28 Aug 2023	15 Aug 2022	04 Dec 2020
Machine Age	Client Info		34	32	0
Oil Age	Client Info		1	0	0
Oil Changed	Client Info		Not Changed	Not Changed	N/A
Sample Status			ATTENTION	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m	>120	0	<1	0
Chromium	ppm ASTM D5185m	>5	0	0	0
Nickel	ppm ASTM D5185m	>20	0	0	0
Titanium	ppm ASTM D5185m		0	0	0
Silver	ppm ASTM D5185m		0	<1	<1
Aluminum	ppm ASTM D5185m	>4	<1	<1	0
Lead	ppm ASTM D5185m	>30	0	0	<1
Copper	ppm ASTM D5185m	>17	0	<1	<1
Tin	ppm ASTM D5185m	>10	0	0	0
Antimony	ppm ASTM D5185m		---	---	0
Vanadium	ppm ASTM D5185m		0	0	0
Cadmium	ppm ASTM D5185m		0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	<1	<1
Barium	ppm ASTM D5185m	0	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0	0
Manganese	ppm ASTM D5185m		0	0	0
Magnesium	ppm ASTM D5185m	5	0	<1	0
Calcium	ppm ASTM D5185m	50	62	89	69
Phosphorus	ppm ASTM D5185m	330	339	356	362
Zinc	ppm ASTM D5185m	420	421	480	438
Sulfur	ppm ASTM D5185m	3100	8374	7875	2350

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m	>25	0	<1	<1
Sodium	ppm ASTM D5185m		<1	<1	0
Potassium	ppm ASTM D5185m	>20	0	<1	0
Water	% ASTM D6304	>0.2	0.002	---	---
ppm Water	ppm ASTM D6304	>2000	18.1	---	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>640	▲ 746	198	97
Particles >6µm	ASTM D7647	>160	▲ 243	57	31
Particles >14µm	ASTM D7647	>20	8	10	4
Particles >21µm	ASTM D7647	>4	1	3	1
Particles >38µm	ASTM D7647	>3	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>16/14/11	▲ 17/15/10	15/13/10	14/12/9


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	.40	0.29	0.26	0.278




OIL ANALYSIS REPORT

Particle Trend



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


Water



FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68.8	59.0	63.3


SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom

Acid Number




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0810916 **Received** : 30 Aug 2023
Lab Number : 05938897 **Diagnosed** : 31 Aug 2023
Unique Number : 10629509 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

Michelin Americas Research Company
 515 Michelin Road
 Greenville, SC
 US 29605
 Contact: Vince Wilson
 vince.wilson@michelin.com
 T: (864)422-3913
 F: (864)422-3518

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)