

## **PROBLEM SUMMARY**

### Sample Rating Trend




FES 1 (S/N 19L635V)

**Refrigeration Compressor** 

USPI 1009-68 SC (--- GAL)

### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS |                |                       |                 |                   |  |  |  |  |
|--------------------------|----------------|-----------------------|-----------------|-------------------|--|--|--|--|
| Sample Status            |                | ABNORMAL              | ABNORMAL        | ABNORMAL          |  |  |  |  |
| Particles >4µm           | ASTM D7647 >   | -10000 <b>△ 26255</b> | <u>▲</u> 168913 | ▲ 100305          |  |  |  |  |
| Particles >6µm           | ASTM D7647 >   | 2500 <b>4750</b>      | <b>48085</b>    | ▲ 17232           |  |  |  |  |
| Oil Cleanliness          | ISO 4406 (c) > | 20/18/15 🛕 22/19/14   | <b>25/23/16</b> | <b>4</b> 24/21/16 |  |  |  |  |

Customer Id: TYSPHIHUN Sample No.: USP0000361 Lab Number: 05938953 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 19 Feb 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 27 Sep 2022 Diag: Doug Bogart

VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. An increase in the viscosity is noted. Confirmed. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



#### 11 Apr 2022 Diag: Doug Bogart

150




Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

Sample Rating Trend



ISO



# FES 1 (S/N 19L635V)

**Refrigeration Compressor** 

USPI 1009-68 SC (--- GAL)

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

|                  |          | Sep2021      | Oct2021 Apr2022 | Sep2022 Feb2023 | Aug2023           |                   |
|------------------|----------|--------------|-----------------|-----------------|-------------------|-------------------|
| SAMPLE INFORM    | MATION   | method       | limit/base      | current         | history1          | history2          |
| Sample Number    |          | Client Info  |                 | USP0000361      | USP246819         | USP242594         |
| Sample Date      |          | Client Info  |                 | 29 Aug 2023     | 19 Feb 2023       | 27 Sep 2022       |
| Machine Age      | hrs      | Client Info  |                 | 0               | 0                 | 0                 |
| Oil Age          | hrs      | Client Info  |                 | 0               | 0                 | 0                 |
| Oil Changed      |          | Client Info  |                 | N/A             | N/A               | N/A               |
| Sample Status    |          |              |                 | ABNORMAL        | ABNORMAL          | ABNORMAL          |
| WEAR METALS      |          | method       | limit/base      | current         | history1          | history2          |
| Iron             | ppm      | ASTM D5185m  | >8              | <1              | 3                 | <1                |
| Chromium         | ppm      | ASTM D5185m  | >2              | 0               | 0                 | 0                 |
| Nickel           | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Titanium         | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Silver           | ppm      | ASTM D5185m  | >2              | 0               | 0                 | 0                 |
| Aluminum         | ppm      | ASTM D5185m  | >3              | <1              | 0                 | 0                 |
| Lead             | ppm      | ASTM D5185m  | >2              | 0               | 0                 | 0                 |
| Copper           | ppm      | ASTM D5185m  | >8              | 0               | 0                 | <1                |
| Tin              | ppm      | ASTM D5185m  | >4              | 0               | 0                 | 0                 |
| Vanadium         | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Cadmium          | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| ADDITIVES        |          | method       | limit/base      | current         | history1          | history2          |
| Boron            | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Barium           | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Molybdenum       | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Manganese        | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Magnesium        | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Calcium          | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Phosphorus       | ppm      | ASTM D5185m  |                 | 0               | 0                 | 0                 |
| Zinc             | ppm      | ASTM D5185m  |                 | 0               | 2                 | <1                |
| Sulfur           | ppm      | ASTM D5185m  | 50              | 0               | 23                | 0                 |
| CONTAMINANTS     | 6        | method       | limit/base      | current         | history1          | history2          |
| Silicon          | ppm      | ASTM D5185m  | >15             | 0               | <1                | 0                 |
| Sodium           | ppm      | ASTM D5185m  |                 | 0               | 0                 | <1                |
| Potassium        | ppm      | ASTM D5185m  | >20             | 0               | 0                 | 0                 |
| Water            | %        | ASTM D6304   | >0.01           | 0.002           | 0.00              | 0.005             |
| ppm Water        | ppm      | ASTM D6304   | >100            | 24.6            | 0.00              | 57.0              |
| FLUID CLEANLIN   | IESS     | method       | limit/base      | current         | history1          | history2          |
| Particles >4µm   |          | ASTM D7647   | >10000          | <b>26255</b>    | <b>△</b> 168913   | ▲ 100305          |
| Particles >6µm   |          | ASTM D7647   | >2500           | <b>4750</b>     | <b>48085</b>      | <u>▲</u> 17232    |
| Particles >14µm  |          | ASTM D7647   | >320            | 105             | <u></u> 405       | <u></u> 512       |
| Particles >21µm  |          | ASTM D7647   | >80             | 20              | 17                | <b>△</b> 93       |
| Particles >38µm  |          | ASTM D7647   | >20             | 0               | 0                 | 1                 |
| Particles >71µm  |          | ASTM D7647   | >4              | 0               | 0                 | 0                 |
| Oil Cleanliness  |          | ISO 4406 (c) | >20/18/15       | <u>22/19/14</u> | <u>△</u> 25/23/16 | <u>4</u> 24/21/16 |
| FLUID DEGRADA    | ATION    | method       | limit/base      | current         | history1          | history2          |
| Acid Number (AN) | mg KOH/g | ASTM D974    | 0.005           | 0.016           | 0.015             | 0.014             |



### **OIL ANALYSIS REPORT**







Certificate L2367

Lab Number **Unique Number** 

Test Package

: 05938953

: 10629565 : IND 2

Diagnosed Diagnostician

: 31 Aug 2023 : Doug Bogart PHILADELPHIA, PA US 19124

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: