

OIL ANALYSIS REPORT

Sample Rating Trend



ATLAS COPCO 5 ATLAS COPCO G160 (S/N WUX410553)

Component

Air Compressor

USPI AIR 46 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2019	May2020 Dec2020	Dec2021 Jun2022 Dec2022	Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM27851	USPM16373	USPM24086
Sample Date		Client Info		26 Aug 2023	28 Jun 2023	25 Dec 2022
Machine Age	hrs	Client Info		53045	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>70	0	0	<1
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>6	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>80	2	<1	2
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	2	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	1	1	<1	0
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	17	38	56
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>12	0	0	3
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	<1
Water	%	ASTM D6304	>0.2	0.086	0.038	0.022
ppm Water	ppm	ASTM D6304	>2000	863.8	380.2	220.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1933	4466	<u></u> 4 36197
Particles >6µm		ASTM D7647	>2500	498	800	<u>▲</u> 8081
Particles >14µm		ASTM D7647	>320	23	22	253
Particles >21µm		ASTM D7647	>80	3	8	54
Particles >38µm		ASTM D7647	>20	0	0	1
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/12	19/17/12	<u>22/20/15</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.21	0.34	0.27



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number

Unique Number

: USPM27851 : 05939012 : 10629624 Test Package : IND 2

Received : 30 Aug 2023 : 05 Sep 2023 Diagnosed

Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HWY 70 North, P.O. Box 272 Columbus Junction, IA US 52738

Contact: STEVE TIGGES

steve.tigges@tyson.com T:

F: (319)753-6235

Contact/Location: STEVE TIGGES - IBPCOL01