




# PROBLEM SUMMARY

Sample Rating Trend

**WEAR**




Machine Id  
**49932627 (S/N 12974)**  
Component  
**Hydraulic System**  
Fluid  
**MOBIL DTE 24 (--- GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Non-ferrous Metals



## RECOMMENDATION

No corrective action is recommended at this time.  
Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

| Sample Status |     |             |     | <b>ABNORMAL</b> | ABNORMAL | --- |
|---------------|-----|-------------|-----|-----------------|----------|-----|
| Copper        | ppm | ASTM D5185m | >20 | <b>▲ 37</b>     | ▲ 30     | --- |

**Customer Id:** TECGRENC  
**Sample No.:** WC0844294  
**Lab Number:** 05939060  
**Test Package:** PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

| Action               | Status | Date | Done By | Description   |
|----------------------|--------|------|---------|---|
| Information Required | ---    | ---  | ?       | Please specify the brand, type, and viscosity of the oil on your next sample. |

## HISTORICAL DIAGNOSIS

26 Sep 2022 Diag: Angela Borella

### WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**49932627 (S/N 12974)**

Component  
**Hydraulic System**

Fluid  
**MOBIL DTE 24 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### ▲ Wear

The copper level is abnormal. All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

| method        | limit/base  | current            | history1    | history2 |
|---------------|-------------|--------------------|-------------|----------|
| Sample Number | Client Info | <b>WC0844294</b>   | WC0731102   | ---      |
| Sample Date   | Client Info | <b>25 Aug 2023</b> | 26 Sep 2022 | ---      |
| Machine Age   | hrs         | Client Info        | 0           | ---      |
| Oil Age       | hrs         | Client Info        | 0           | ---      |
| Oil Changed   | Client Info | <b>N/A</b>         | N/A         | ---      |
| Sample Status |             | <b>ABNORMAL</b>    | ABNORMAL    | ---      |

## WEAR METALS

| method   | limit/base | current         | history1     | history2    |     |
|----------|------------|-----------------|--------------|-------------|-----|
| PQ       | ASTM D8184 | <b>13</b>       | ---          | ---         |     |
| Iron     | ppm        | ASTM D5185m >20 | <b>9</b>     | 8           | --- |
| Chromium | ppm        | ASTM D5185m >20 | <b>0</b>     | 0           | --- |
| Nickel   | ppm        | ASTM D5185m >20 | <b>&lt;1</b> | 0           | --- |
| Titanium | ppm        | ASTM D5185m     | <b>0</b>     | 0           | --- |
| Silver   | ppm        | ASTM D5185m     | <b>0</b>     | 0           | --- |
| Aluminum | ppm        | ASTM D5185m >20 | <b>0</b>     | <1          | --- |
| Lead     | ppm        | ASTM D5185m >20 | <b>9</b>     | 7           | --- |
| Copper   | ppm        | ASTM D5185m >20 | <b>▲ 37</b>  | <b>▲ 30</b> | --- |
| Tin      | ppm        | ASTM D5185m >20 | <b>2</b>     | 2           | --- |
| Vanadium | ppm        | ASTM D5185m     | <b>0</b>     | 0           | --- |
| Cadmium  | ppm        | ASTM D5185m     | <b>0</b>     | 0           | --- |

## ADDITIVES

| method     | limit/base | current     | history1     | history2 |     |
|------------|------------|-------------|--------------|----------|-----|
| Boron      | ppm        | ASTM D5185m | <b>0</b>     | <1       | --- |
| Barium     | ppm        | ASTM D5185m | <b>3</b>     | 4        | --- |
| Molybdenum | ppm        | ASTM D5185m | <b>1</b>     | 1        | --- |
| Manganese  | ppm        | ASTM D5185m | <b>&lt;1</b> | <1       | --- |
| Magnesium  | ppm        | ASTM D5185m | <b>15</b>    | 12       | --- |
| Calcium    | ppm        | ASTM D5185m | <b>152</b>   | 131      | --- |
| Phosphorus | ppm        | ASTM D5185m | <b>635</b>   | 555      | --- |
| Zinc       | ppm        | ASTM D5185m | <b>914</b>   | 774      | --- |
| Sulfur     | ppm        | ASTM D5185m | <b>5129</b>  | 4673     | --- |

## CONTAMINANTS

| method    | limit/base | current         | history1  | history2 |     |
|-----------|------------|-----------------|-----------|----------|-----|
| Silicon   | ppm        | ASTM D5185m >15 | <b>14</b> | 13       | --- |
| Sodium    | ppm        | ASTM D5185m     | <b>0</b>  | 0        | --- |
| Potassium | ppm        | ASTM D5185m >20 | <b>2</b>  | 2        | --- |

## FLUID CLEANLINESS




| method          | limit/base   | current   | history1        | history2 |     |
|-----------------|--------------|-----------|-----------------|----------|-----|
| Particles >4µm  | ASTM D7647   | >5000     | <b>431</b>      | 1217     | --- |
| Particles >6µm  | ASTM D7647   | >1300     | <b>76</b>       | 193      | --- |
| Particles >14µm | ASTM D7647   | >160      | <b>15</b>       | 12       | --- |
| Particles >21µm | ASTM D7647   | >40       | <b>7</b>        | 1        | --- |
| Particles >38µm | ASTM D7647   | >10       | <b>0</b>        | 0        | --- |
| Particles >71µm | ASTM D7647   | >3        | <b>0</b>        | 0        | --- |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14 | <b>16/13/11</b> | 17/15/11 | --- |

## FLUID DEGRADATION

| method           | limit/base | current    | history1    | history2 |     |
|------------------|------------|------------|-------------|----------|-----|
| Acid Number (AN) | mg KOH/g   | ASTM D8045 | <b>0.80</b> | 0.86     | --- |




# OIL ANALYSIS REPORT








| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | ---      |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | ---      |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | ---      |
| Silt             | scalar | *Visual    | NONE    | NONE     | ---      |
| Debris           | scalar | *Visual    | NONE    | NONE     | ---      |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | ---      |
| Appearance       | scalar | *Visual    | NORML   | NORML    | ---      |
| Odor             | scalar | *Visual    | NORML   | NORML    | ---      |
| Emulsified Water | scalar | *Visual    | >0.05   | NEG      | ---      |
| Free Water       | scalar | *Visual    |         | NEG      | ---      |

| FLUID PROPERTIES | method | limit/base | current | history1    | history2 |
|------------------|--------|------------|---------|-------------|----------|
| Visc @ 40°C      | cSt    | ASTM D445  | 31.5    | <b>31.7</b> | 32.4     |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0844294 **Received** : 30 Aug 2023  
**Lab Number** : 05939060 **Diagnosed** : 27 Sep 2023  
**Unique Number** : 10629672 **Diagnostician** : Doug Bogart  
**Test Package** : PLANT

**TE CONNECTIVITY**  
 719 PEGG RD  
 GREENSBORO, NC  
 US 27409  
 Contact: BILLIE WALLACE  
 billie.wallace@te.com  
 T:  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)