




# COOLANT REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**MTNGPBL02**

Component  
**2 Coolant**  
Fluid

**EXTENDED LIFE COOLANT (--- GAL)**

## DIAGNOSIS

### Recommendation

The fluid is suitable for further service.

### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.

### Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0775120</b>	WC0675519	WC0566311
Sample Date	Client Info	<b>20 Sep 2023</b>	13 Sep 2022	10 Jan 2022
Machine Age	hrs Client Info	<b>90518</b>	38540	90518
Oil Age	hrs Client Info	<b>90518</b>	38540	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## PHYSICAL TEST RESULTS

method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	<b>1.069</b>	1.067	---
pH	Scale 0-14 ASTM D1287	<b>8.11</b>	8.68	9.17
Nitrites	ppm AP-053:2009	<b>1052</b>	1840	788
Reserve Alkalinity	Scale 0-20 *ASTM D1121	<b>---</b>	---	---
Percentage Glycol	% ASTM D3321	<b>51.9</b>	49.2	45
Freezing Point	°F ASTM D3321	<b>-38</b>	-33	-25
Total Dissolved Solids		<b>343.5</b>	379.0	256.0
Carboxylate		<b>n/a</b>	pass	n/a

## CORROSION INHIBITORS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D6130	<b>76</b>	63	123
Phosphorus	ppm ASTM D6130	<b>366</b>	1229	87
Boron	ppm ASTM D6130	<b>236</b>	270	495
Molybdenum	ppm ASTM D6130	<b>488</b>	325	13

## CORROSION

method	limit/base	current	history1	history2
Iron	ppm ASTM D6130 >15	<b>4</b>	0	<1
Aluminum	ppm ASTM D6130 >10	<b>&lt;1</b>	0	0
Copper	ppm ASTM D6130 >10	<b>&lt;1</b>	1	<1
Lead	ppm ASTM D6130 >10	<b>&lt;1</b>	0	0
Tin	ppm ASTM D6130 >10	<b>&lt;1</b>	0	0
Zinc	ppm ASTM D6130	<b>&lt;1</b>	<1	<1

## CONTAMINANTS

method	limit/base	current	history1	history2
Chlorine	ppm ASTM D6130	<b>17</b>	8	<1

## CARRIER SALTS


method	limit/base	current	history1	history2
Sodium	ppm ASTM D6130	<b>2333</b>	2240	1767
Potassium	ppm ASTM D6130	<b>6008</b>	1107	170







## SCALE POTENTIAL

method	limit/base	current	history1	history2
Calcium	ppm ASTM D6130	<b>2</b>	0	0
Magnesium	ppm ASTM D6130	<b>&lt;1</b>	1	0









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	Pink	Pink
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0775120 **Received** : 22 Sep 2023  
**Lab Number** : 05959318 **Diagnosed** : 26 Sep 2023  
**Unique Number** : 10660531 **Diagnostician** : Doug Bogart  
**Test Package** : COOL- ( Additional Tests: COOL, ICP )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**EDL NA Recips-Morgantown**  
 Morgantown Powerstation, 950 Shiloh  
 Morgantown, PA  
 US 19543  
 Contact: ARON GUNN  
 aron.gunn@edlenergy.com

T:  
F: