

PROBLEM SUMMARY

Built for a lifetime."


KAESER BSD 60 6870265 (S/N 1528)


Compressor


Fluid



COMPONENT CONDITION SUMMARY







RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

FROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Water	%	ASTM D6304	>0.05	A 0.135	0.022	0.010	
ppm Water	ppm	ASTM D6304	>500	A 1350	228.1	105.3	
Particles >6µm		ASTM D7647	>1300	<u> </u>		A 2569	
Particles >14µm		ASTM D7647	>80	A 319		🔺 191	
Particles >21µm		ASTM D7647	>20	<u> </u>		<u> </u>	
Particles >38µm		ASTM D7647	>4	<u> </u>		1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		2 1/19/15	

Customer Id: NEWWESFL Sample No.: KC05959804 Lab Number: 05959804 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

18 May 2023 Diag: Don Baldridge

VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



12 Oct 2022 Diag: Doug Bogart

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition


The AN level is acceptable for this fluid.




SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05959804	KC111611	KC85700
Sample Date		Client Info		01 Sep 2023	18 May 2023	12 Oct 2022
Machine Age	hrs	Client Info		27240	26601	22706
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	4	3
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	40	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	10	54	0
Calcium	ppm	ASTM D5185m	2	0	2	0
Phosphorus	ppm	ASTM D5185m		4	0	0
Zinc	ppm	ASTM D5185m		89	14	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		<1	5	<1
Potassium	ppm	ASTM D5185m	>20	2	6	0
Water	%	ASTM D6304	>0.05	A 0.135	0.022	0.010
ppm Water	ppm	ASTM D6304	>500	1350	228.1	105.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3436		10064
Particles >6µm		ASTM D7647		<u> </u>		▲ 2569
Particles >14µm		ASTM D7647	>80	A 319		1 91
Particles >21µm		ASTM D7647	>20	<u> </u>		▲ 50
Particles >38µm		ASTM D7647	>4	<u> </u>		1
		ACTM D7647	>3	•		0
Particles >71µm		ASTM D7647		2		
Particles >71µm Oil Cleanliness		ISO 4406 (c)	>/17/13	2 ▲ 19/18/15		↓ 21/19/15



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	🔺 MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.9	43.2	43.7
SAMPLE IMAGES		method	limit/base	current	history1	history2
0 1						



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: W. HOLTZCLAW - NEWWESFL

F: