



## **PROBLEM SUMMARY**


# COMPAIR LEROI EVIS COMPAIR LEROI 100HP (S/N 4541X65)

Air Compressor Fluid USPI AIR 46 (--- GAL)

## COMPONENT CONDITION SUMMARY







## RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	NORMAL		
Phosphorus	ppm	ASTM D5185m	1	<u> </u>	175	2		
Particles >4µm		ASTM D7647	>10000	<b>A</b> 134020		5481		
Particles >6µm		ASTM D7647	>2500	<u> </u>		631		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u> </u>		20/16/11		

Customer Id: TYSBLOAL Sample No.: USP0001933 Lab Number: 05959813 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

## **HISTORICAL DIAGNOSIS**

## 19 Jul 2023 Diag: Doug Bogart



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. An increase in the phosphorus level is noted. Confirmed. The AN level is acceptable for this fluid.



view report

## 02 May 2023 Diag: Doug Bogart



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

09 Nov 2022 Diag: Jonathan Hester



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







## **OIL ANALYSIS REPORT**

# COMPAIR LEROI EVIS COMPAIR LEROI 100HP (S/N 4541X65)

Air Compressor

Fluid USPI AIR 46 (--- GAL)

## DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor.

## Wear


All component wear rates are normal.

## Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

## Fluid Condition


Phosphorus confirmed. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





Sample Number Sample Date	MATION	method	limit/base	current	history1	history2
		Client Info		USP0001933	USPM29021	USPM28830
		Client Info		24 Sep 2023	19 Jul 2023	02 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	4	0
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	1	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	2	<1	0
Tin	ppm	ASTM D5185m	>5	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	0	0	<1	<1
Calcium	ppm	ASTM D5185m	0	0	<1	0
Phosphorus	ppm	ASTM D5185m	1	<u> </u>	175	2
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	0	0	0
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	<1	1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>0.2	0.126	▲ 0.260	0.109
ppm Water	ppm	ASTM D6304	>2000	1269.4	<b>A</b> 2600	1095.6
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
		ASTM D7647	>10000	<b>134020</b>		5481
Particles >4µm		ASTM D7647	>2500	<u> </u>		631
Particles >4μm Particles >6μm Particles >14μm		ASTM D7647	>320	212		13
Particles >6µm		ASTM D7647 ASTM D7647	>320 >80	212 31		13 3
Particles >6μm Particles >14μm Particles >21μm						
Particles >6µm Particles >14µm		ASTM D7647	>80 >20	31		3
Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm		ASTM D7647 ASTM D7647	>80 >20	31 2		3 0
Particles >6μm Particles >14μm Particles >21μm Particles >38μm	ATION	ASTM D7647 ASTM D7647 ASTM D7647	>80 >20 >4	31 2 0		3 0 0



# **OIL ANALYSIS REPORT**







(B/HO) Bull (B/HO) (B/H

Pio 0.10

0.00

3500

3000

2500

특 2000

Nate Mate

1000

500


ct18/18

Base 0.05


Oct18/18

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	🔺 MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.7	50.3	56.9	50.3
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
				pir - Evis Ca		

Color



Bottom



Contact/Location: SERVICE MANAGER - TYSBLOAL