

FUEL REPORT

Sample Rating Trend

ISO

KIOTI CK4010 YR70-00325

Diesel Fuel Fluid NOT GIVEN (--- GAL)

DIAGNOSIS

A Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

				Sep2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0000687		
Sample Date		Client Info		24 Sep 2023		
Machine Age	hrs	Client Info		0		
Sample Status				ATTENTION		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.840		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445		2.4		
Pensky-Martens Flash Point	°C	*PMCC Calculated		56		
SULFUR CONTER	T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		13		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		157		
5% Distillation Point	°C	ASTM D86		186		
10% Distill Point	°C	ASTM D86		198		
15% Distillation Point	°C	ASTM D86		207		
20% Distill Point	°C	ASTM D86		215		
30% Distill Point	°C	ASTM D86		229		
40% Distill Point	°C	ASTM D86		243		
50% Distill Point	°C	ASTM D86		257		
60% Distill Point	°C	ASTM D86		272		
70% Distill Point	°C	ASTM D86		287		
80% Distill Point	°C	ASTM D86		305		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86		327		
95% Distillation Point	°C	ASTM D86		345		
Final Boiling Point	°C	ASTM D86		354		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.9		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.0		
Cetane Index		ASTM D4737	<40.0	47.8		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	2		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	<0.05	0.003		
ppm Water	ppm	ASTM D6304	<500	38.2		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT

Particle Count	r26	FLUID CLEANL	INESS	method	limit/base	current	history1	
	-24	Particles >4µm		ASTM D7647	>2500	3684		
Severe	-22 8	Particles >6µm		ASTM D7647	>640	1536		
Abnormal	-20 0 4406:1999 -20 Clean -18 999 Clean -16 Clean -14 min	Particles >14µm		ASTM D7647	>80	A 273		
	-16 Q	Particles >21µm		ASTM D7647	>20	<u> </u>		
	-14	Particles >38µm		ASTM D7647	>4	3		
	-12 25 Cod	Particles >71µm		ASTM D7647	>3	0		
	-8	Oil Cleanliness		ISO 4406 (c)	>18/16/13	^ 19/18/15		
6µ 14µ 21µ	38µ 71µ	HEAVY METAL	S	method	limit/base	current	history1	
article Trend		Aluminum	ppm	ASTM D5185m	<0.1	<1		
4μm 6μm		Nickel	ppm	ASTM D5185m	<0.1	0		
ormal 14µm		Lead	ppm	ASTM D5185m	<0.1	0		
		Vanadium	ppm	ASTM D5185m	<0.1	0		
		Iron	ppm	ASTM D5185m	<0.1	0		
		Calcium	ppm	ASTM D5185m	<0.1	0		
		Magnesium	ppm	ASTM D5185m	<0.1	0		
	4/23	Phosphorus	ppm	ASTM D5185m	<0.1	1		
	Sep24/23	Zinc	ppm	ASTM D5185m	<0.1	0		
er (KF)		SAMPLE IMAG	ES	method	limit/base	current	history1	
8		Color					no image	n
normal	Sep24/23	Bottom					no image	n
57 /t-7 dao	õ	GRAPHS						
Viscosity @ 40°C	30	Fuel Distillation (Curve		ç ⁷	Pensky-Marten	s Flash Point ((°C)
		Sample				50 -		
Abnormal		0°CBaseline				50 -		
	şi	0°C -			in the second se	10		
bnormal	20	0°C -		1	· · · · ·	Sep 24/23		
	Di	0°C -		1		Seb		
		0°C -		1				
			/					
	Sep 24/23	0°C -	/					
		0°C						
Distillation Curve	۲ <u>۲</u>	0°C						
Sample	20	D°C						
Baseline	-							
	18	/						
-t-t-t	16	0°C 4						
	14	0°C -						
	12	0°C						
10%	60% - 90% -	0% 10% 20% 30%	40% 50%		90% 100%			
Percent Recovere			Percent Recovered					
	Laboratory Sample No. Lab Number Unique Number	: WearCheck USA - : KT0000687 : 05960259 : 10661472	- 501 Madis Received Diagnose Diagnost	l : 25 (ed : 02 (ry, NC 2751 Sep 2023 Oct 2023 Ig Bogart	3	MASON 1050 APPA BL	
H 67 1-8	Test Deskere	DE 0 (Additional	Tastas Cara		J		0	

Test Package : DF-2 (Additional Tests: Screen) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TRACTOR CO LACHIAN HWY UE RIDGE, GA US 30513 Contact: CELESTE JONES celestejones@masontractorco.com T: (706)632-3777 F:

Contact/Location: CELESTE JONES - MASBLU

history2

history2

history2

no image

no image

Sep24/23 -